

NFPA® 1989

Standard on Breathing Air Quality for Emergency Services Respiratory Protection

2013 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
An International Codes and Standards Organization

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® DOCUMENTS
NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA DOCUMENTS

NFPA® codes, standards, recommended practices, and guides (“NFPA Documents”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Documents.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Documents. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Documents available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Documents. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REMINDER: UPDATING OF NFPA DOCUMENTS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Documents”) should be aware that NFPA Documents may be amended from time to time through the issuance of Tentative Interim Amendments or corrected by Errata. An official NFPA Document at any point in time consists of the current edition of the document together with any Tentative Interim Amendment and any Errata then in effect.

In order to determine whether an NFPA Document has been amended through the issuance of Tentative Interim Amendments or corrected by Errata, visit the Document Information Pages on NFPA’s website. The Document Information Pages provide up-to-date, document specific information including any issued Tentative Interim Amendments and Errata.

To access the Document Information Page for a specific NFPA Document go to <http://www.nfpa.org/document> for a list of NFPA Documents, and click on the appropriate Document number (e.g., NFPA 101). In addition to posting all existing Tentative Interim Amendments and Errata, the Document Information Page also includes the option to sign-up for an “Alert” feature to receive an email notification when new updates and other information are posted regarding the document.

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® DOCUMENTS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Documents”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA Document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Document. The users of NFPA Documents bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Documents.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Document may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Documents are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Documents for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Documents and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org

For more information about NFPA, visit the NFPA website at www.nfpa.org.

Copyright © 2013 National Fire Protection Association®. All Rights Reserved.

NFPA® 1989

Standard on

Breathing Air Quality for Emergency Services Respiratory Protection

2013 Edition

This edition of NFPA 1989, *Standard on Breathing Air Quality for Emergency Services Respiratory Protection*, was prepared by the Technical Committee on Respiratory Protection Equipment and released by the Technical Correlating Committee on Fire and Emergency Services Protective Clothing and Equipment. It was issued by the Standards Council on November 27, 2012, with an effective date of December 17, 2012, and supersedes all previous editions.

This edition of NFPA 1989 was approved as an American National Standard on December 17, 2012.

Origin and Development of NFPA 1989

In 1999, the NFPA Standards Council assigned the responsibility of documents covering breathing air quality for respiratory protection to the Technical Committee on Respiratory Protection and Personal Alarm Equipment. Previously, three documents, NFPA 1404, NFPA 1500, and NFPA 1981, carried different requirements about breathing air quality.

The Technical Committee developed this new standard, NFPA 1989, with the goal of establishing a single set of requirements for the quality of breathing air used in atmosphere-supplying respirators, including open-circuit self-contained breathing apparatus (SCBA), used by fire and emergency services personnel.

The first edition was acted on by the NFPA membership at the Fall Meeting in Atlanta, GA, on November 20, 2002.

In the second (2008) edition, the title of NFPA 1989 was modified to *Standard on Breathing Air Quality for Emergency Services Respiratory Protection*. In that edition, a new Chapter 7 was added that specifies requirements for a compressed breathing system. The chapter covers installation, compressors, maintenance, and records for the system. All air quality requirements and testing criteria were reviewed and refined to better assure high-quality breathing air for emergency services personnel.

The 2008 edition of NFPA 1989 was issued with an effective date of December 31, 2007.

The 2013 (third) edition of NFPA 1989 includes new requirements for air storage cylinders, air sampling requirements, and cylinder recharge areas posting requirements, as well as editorial revisions.

The 2013 edition of NFPA 1989 was issued with an effective date of December 17, 2012.

Technical Correlating Committee on Fire and Emergency Services Protective Clothing and Equipment

William E. Haskell, III, *Chair*

National Institute for Occupational Safety & Health, MA [E]

Eric J. Beck, *Secretary*

Mine Safety Appliances Company, PA [M]

Jason L. Allen, Intertek Testing Services, NY [RT]

Roger L. Barker, North Carolina State University, NC [SE]

Brian D. Berchtold, U.S. Department of the Navy, DE [RT]

Steven D. Corrado, UL LLC, NC [RT]

Nicholas J. Curtis, Lion Apparel, Inc., OH [M]

Richard M. Duffy, International Association of Fire Fighters, DC [L]

Cristine Z. Fargo, International Safety Equipment Association, VA [M]

Robert A. Freese, Globe Manufacturing Company, NH [M]

Patricia A. Gleason, Safety Equipment Institute (SEI), VA [RT]

David V. Haston, U.S. Department of Agriculture, U.S. Forest Service, CA [E]

Kimberly M. Henry, PBI Performance Products, Inc., NC [M]

James S. Johnson, Lawrence Livermore National Laboratory, CA [RT]

David G. Matthews, Fire & Industrial (P.P.E) Ltd., United Kingdom [SE]

Rep. International Standards Organization

Michael F. McKenna, Michael McKenna & Associates, LLC, CA [SE]

Gary L. Neilson, Sparks, NV [U]

Rep. NFPA Fire Service Section

Anthony D. Putorti, Jr., National Institute of Standards & Technology, MD [RT]

Jeffrey O. Stull, International Personnel Protection, Inc., TX [M]

William A. Van Lent, Veridian Ltd., Inc., IA [M]

Rep. Fire & Emergency Manufacturers & Services Association

Alternates

Leslie Anderson, U.S.D.A. Forest Service, MT [E]

(Alt. to D. V. Haston)

Chris Bain, Oklahoma State Firefighters Association, OK [C]

(Voting Alt. to OSFA Rep.)

Louis Carpentier, Innotex Inc., Canada [M]

(Alt. to W. A. Van Lent)

Brandi L. Chestang, U.S. Department of the Navy, FL [RT]

(Alt. to B. D. Berchtold)

Patricia A. Freeman, Globe Manufacturing Company, LLC, NH [M]

(Alt. to R. A. Freese)

Pamela A. Kavalesky, Intertek Testing Services, NY [RT]

(Alt. to J. L. Allen)

Karen E. Lehtonen, Lion Apparel, Inc., OH [M]

(Alt. to N. J. Curtis)

Robin B. Royster, UL LLC, NC [RT]

(Alt. to S. D. Corrado)

Michael T. Rupert, Mine Safety Appliances Company, PA [M]

(Alt. to E. J. Beck)

Stephen R. Sanders, Safety Equipment Institute (SEI), VA [RT]

(Alt. to P. A. Gleason)

Grace G. Stull, International Personnel Protection, Inc., TX [M]

(Alt. to J. O. Stull)

Donald B. Thompson, North Carolina State University, NC [SE]

(Alt. to R. L. Barker)

Richard H. Young, DuPont Protection Technologies, VA [M]

(Alt. to K. M. Henry)

Nonvoting

Christina M. Baxter, U.S. Department of Defense, VA [E]

Rep. TC on Hazardous Materials PC & E

Dean W. Cox, Fairfax County Fire & Rescue Department, VA [U]

Rep. TC on Special Operations PC & E

Stephen J. King, Babylon, NY [SE]

Rep. TC on Structural and Proximity Fire Fighting PC & E

Daniel N. Rossos, Portland Fire & Rescue, OR [U]

Rep. TC on Respiratory Protection Equipment

Rick L. Swan, IAFF Local 2881/CDF Fire Fighters, CA [L]

Rep. TC on Wildland Fire Fighting PC & E

Bruce H. Varner, Goodyear, AZ [E]

Rep. TC on Electronic Safety Equipment

David G. Trebisacci, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on the design, performance, testing, and certification of protective clothing and protective equipment manufactured for fire and emergency services organizations and personnel, to protect against exposures encountered during emergency incident operations. This Committee shall also have the primary responsibility for documents on the selection, care, and maintenance of such protective clothing and protective equipment by fire and emergency services organizations and personnel.



Technical Committee on Respiratory Protection Equipment

Daniel N. Rossos, *Chair*
Portland Fire & Rescue, OR [U]

Steven H. Weinstein, *Secretary*
Honeywell Safety Products, CA [M]
Rep. International Safety Equipment Association

Heinz W. Ahlers, National Institute for Occupational Safety & Health, PA [E]
Jason L. Allen, Intertek Testing Services, NY [RT]
Christopher Anaya, Sacramento Metropolitan Fire Department, CA [C]
Rep. California State Firefighters Association
David T. Bernzweig, Columbus (OH) Division of Fire, OH [L]
Rep. Columbus Firefighters Union
W. Lee Birch, Luxfer Gas Cylinders, CA [M]
A. Paul Bull, Charles Town, WV [SE]
Rodney V. Colbert, Fairfax County Fire & Rescue Department, VA [U]
Brian H. Cox, Clovis Fire Department, CA [U]
William Dickson, Bauer Compressors, Inc., VA [M]
Robin R. Gainey, Jacksonville Fire Rescue Department, FL [L]
Rep. International Association of Fire Fighters
Deborah L. Gaudet, City of Virginia Beach Fire Department, VA [U]
Ed Golla, TRI/Air Testing, TX [RT]

A. Ira Harkness, U.S. Department of the Navy, FL [RT]
David V. Haston, U.S. Department of Agriculture, U.S. Forest Service, CA [RT]
John Jarboe, Grace Industries, Inc., MD [M]
James S. Johnson, Lawrence Livermore National Laboratory, CA [RT]
Clint Kaller, Los Angeles County Fire Department, CA [U]
Craig Martin, Avon-ISI, GA [M]
Ian Maxwell, Interspiro AB, Sweden [M]
Stephen T. Miles, National Institute for Occupational Safety & Health, WV [E]
Ruby Ochoa, Trace Analytics LLC, TX [RT]
Jerry Phifer, Tyco/Scott Health & Safety, NC [M]
Samuel C. Pitts, U.S. Marine Corps Systems Command, VA [E]
Timothy M. Radtke, U.S. Department of the Interior, CO [E]
Michael T. Rupert, Mine Safety Appliances Company, PA [M]
Stephen R. Sanders, Safety Equipment Institute (SEI), VA [RT]
Robert Sell, Draeger Safety, Inc., PA [M]
Richard S. Tobin, Jr., Fire Department City of New York, NY [U]
Kenton D. Warner, KDW Consulting, LLC, FL [SE]

Alternates

Marshall J. Black, U.S. Department of the Navy, FL [RT]
(Alt. to A. I. Harkness)
John P. Campman, Grace Industries, Inc., PA [M]
(Alt. to J. Jarboe)
J. Michael Carlson, TRI Air Testing, TX [RT]
(Alt. to E. Golla)
Craig E. Colton, 3M Company, MN [M]
(Alt. to S. H. Weinstein)
Dennis K. Davis, U.S. Department of Agriculture, MT [RT]
(Alt. to D. V. Haston)
Orion S. Goe, Luxfer Gas Cylinders, CA [M]
(Alt. to W. L. Birch)
Beverly F. Gullledge, Tyco/Scott Safety, NC [M]
(Alt. to J. Phifer)
David Hodson, Draeger Safety UK Ltd., United Kingdom [M]
(Alt. to R. Sell)
George Hoppe, Jr., Bauer Compressors, Inc., VA [M]
(Alt. to W. Dickson)
Todd Keathley, Portland Fire & Rescue, OR [U]
(Alt. to D. N. Rossos)

John F. Kuhn, Mine Safety Appliances Company, PA [M]
(Alt. to M. T. Rupert)
Beth C. Lancaster, U.S. Marine Corps Systems Command, VA [E]
(Alt. to S. C. Pitts)
Clint Mayhue, International Safety Instruments (ISI), GA [M]
(Alt. to C. Martin)
Dean D. Moran, Safety Equipment Institute (SEI), VA [RT]
(Alt. to S. R. Sanders)
Chad A. Morey, Intertek Testing Services, NY [RT]
(Alt. to J. L. Allen)
William T. Mundy, Fire Department City of New York, NY [U]
(Alt. to R. S. Tobin, Jr.)
Kenneth A. Pravetz, City of Virginia Beach Fire Department, VA [U]
(Alt. to D. L. Gaudet)
Dick Smith, Trace Analytics LLC, TX [RT]
(Alt. to R. Ochoa)
Jonathan V. Szalajda, National Institute for Occupational Safety & Health, PA [E]
(Alt. to H. W. Ahlers)

Nonvoting

Matthew I. Chibbaro, U.S. Department of Labor, DC [E]

John Steelack, U.S. Department of Labor, DC [E]
(Alt. to M. I. Chibbaro)
Rep. Occupational Safety & Health Administration

David G. Trebisacci, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on respiratory equipment, including breathing air, for fire and emergency services personnel during incidents involving hazardous or oxygen deficient atmospheres. This Committee shall also have primary responsibility for documents on the selection, care, and maintenance of respiratory protection equipment and systems by fire and emergency services organizations and personnel.

Contents

Chapter 1 Administration	1989- 5	5.4 Special Testing and Procedures for Contaminated Compressed Breathing Air	1989- 7
1.1 Scope	1989- 5	5.5 Air Samples	1989- 8
1.2 Purpose	1989- 5	5.6 Breathing Air Quality Requirements	1989- 8
1.3 Application	1989- 5	5.7 Posting Requirements.	1989- 8
1.4 Units	1989- 5		
Chapter 2 Referenced Publications	1989- 6	Chapter 6 Test Methods	1989- 8
2.1 General	1989- 6	6.1 Oxygen Content Test	1989- 8
2.2 NFPA Publications	1989- 6	6.2 Carbon Monoxide Content Test	1989- 9
2.3 Other Publications	1989- 6	6.3 Carbon Dioxide Content Test	1989- 9
2.4 References for Extracts in Mandatory Sections. (Reserved)	1989- 6	6.4 Condensed Oil and Particulate Content Test	1989- 9
Chapter 3 Definitions	1989- 6	6.5 Water Concentration Test	1989- 9
3.1 General	1989- 6	6.6 Hydrocarbon Content Test	1989-10
3.2 NFPA Official Definitions	1989- 6	6.7 Determination of Odor Test	1989-10
3.3 General Definitions	1989- 6	6.8 Nitrogen Content Test	1989-10
Chapter 4 Accreditation	1989- 6	Chapter 7 Compressed Breathing Air Systems ...	1989-10
4.1 General	1989- 6	7.1 Installation	1989-10
4.2 Accreditation Program	1989- 7	7.2 Compressors	1989-10
Chapter 5 Air Quality Requirements	1989- 7	7.3 Maintenance	1989-11
5.1 Regular Periodic Testing	1989- 7	7.4 Records	1989-11
5.2 Special Testing and Procedures for Maintenance Conditions	1989- 7	Annex A Explanatory Material	1989-11
5.3 Special Testing and Procedures for Synthetic Breathing Air	1989- 7	Annex B Informational References (Reserved)	1989-13
		Index	1989-15

NFPA 1989**Standard on****Breathing Air Quality for Emergency Services
Respiratory Protection****2013 Edition**

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Documents.” They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

Changes other than editorial are indicated by a vertical rule beside the paragraph, table, or figure in which the change occurred. These rules are included as an aid to the user in identifying changes from the previous edition. Where one or more complete paragraphs have been deleted, the deletion is indicated by a bullet (•) between the paragraphs that remain.

Information on referenced publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration**1.1* Scope.**

1.1.1 This standard shall specify the minimum requirements for breathing air quality for emergency services organizations that use atmosphere-supplying respirators for the respiratory protection of their personnel.

1.1.2 This standard shall specify the requirements for the breathing air quality component of the respiratory protection program of any emergency services organization.

1.1.3 For fire departments, this standard shall specify the requirements for the breathing air quality component of the respiratory protection program required by NFPA 1500, *Standard on Fire Department Occupational Safety and Health Program*.

1.1.4 This standard shall not specify requirements for medical-grade oxygen.

1.1.5 This standard shall not specify requirements for air quality for any other applications.

1.1.6 This standard shall not be construed as addressing all of the safety concerns, if any, associated with its use. It shall be the responsibility of the persons and organizations that use this standard to establish safety and health practices and determine the applicability of regulatory limitations prior to use of this standard.

1.1.7 This standard shall not be construed as addressing all of the safety concerns associated with the use of atmosphere-supplying respirators and compliant breathing air supplies for the respiratory protection of their personnel. It shall be the responsibility of the persons and organizations that use compliant breathing air supplies to establish safety and health

practices and determine the applicability of regulatory limitations prior to use.

1.1.8 This standard shall not be construed as addressing all of the safety concerns, if any, associated with the use of this standard by testing facilities. It shall be the responsibility of the persons and organizations that use this standard to conduct testing of breathing air and breathing air supply systems to establish safety and health practices and determine the applicability of regulatory limitations prior to using this standard for any designing, manufacturing, and testing.

1.1.9 Nothing herein shall restrict any jurisdiction or breathing air provider from exceeding these minimum requirements.

1.2 Purpose.

1.2.1 The purpose of this standard shall be to establish minimum quality requirements for breathing air, including the sampling and testing methods for determining breathing air quality.

1.2.2 The purpose of this standard shall also be to establish criteria for a safe supply of breathing air for emergency services personnel who use atmosphere-supplying respirators that provide life support during rescue; confined space operations; hazardous materials operations; technical rescue operations; fire fighting operations; chemical, biological, radiological, and nuclear radiation (CBRN) terrorism incident operations; and special operations where respiratory hazards can or do exist.

1.3 Application.

1.3.1 This standard shall apply to atmosphere-supplying respirators that provide the breathing air supply from a compressed breathing gas source that is independent of the ambient atmosphere.

1.3.1.1 This standard shall apply to atmosphere-supplying respirators used by emergency service organizations for respiratory protection of their personnel.

1.3.1.2 This standard shall apply to all compressed normal atmospheric air and all compressed synthetic breathing air regardless of the source of the breathing air.

1.3.2 Where fire fighters encounter an air pipeline with or without a compressor or cascade, they shall take whatever action necessary to ensure the air in this system meets the air quality standards outlined in this standard.

1.3.3 For fire departments, this standard shall also apply to the requirements for breathing air quality component of the fire department's respiratory protection program as required by Section 7.10 of NFPA 1500, *Standard on Fire Department Occupational Safety and Health Program*.

1.3.4 This standard shall not apply to medical-grade oxygen used in patient care during emergency medical incidents and other pre-hospital or hospital patient care.

1.3.5 This standard shall not apply to air quality for any other purposes, including, but not limited to, industrial applications, utility applications, diving, pneumatic processes, cleaning, drying, and inflating.

1.4 Units.

1.4.1 In this standard, values for measurement are followed by an equivalent in parentheses, but only the first stated value shall be regarded as the requirement.

1.4.2 Equivalent values in parentheses shall not be considered as the requirement as these values are approximate.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 1500, *Standard on Fire Department Occupational Safety and Health Program*, 2013 edition.

2.3 Other Publications.

2.3.1 ASTM Publications. ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D 2986, *Standard Practice for Evaluation of Air Assay Media by the Monodisperse DOP (Diocetyl Phthalate) Smoke Test*, 1995.

2.3.2 ISO Publications. International Organization for Standardization, 1, Ch. de la Voie-Creuse, Case postale 56, CH-1211 Geneva 20, Switzerland.

ISO 17025, *General requirements for the competence of calibration and testing laboratories*, 1999.

2.3.3 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections. (Reserved)

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1 Shall. Indicates a mandatory requirement.

3.2.2 Should. Indicates a recommendation or that which is advised but not required.

3.2.3 Standard. A document, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and which is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the *Manual of Style for NFPA Technical Committee Documents*.

3.3 General Definitions.

3.3.1 Accreditation/Accredited. A program by which an accreditation body determines that a laboratory has demonstrated the ability to conduct testing as required by this standard.

3.3.2 Accreditation Body. An independent, third-party organization that determines the qualification of laboratories to conduct testing as required by this standard.

3.3.3 Air Storage. ASME receivers and/or DOT cylinders with a capacity in excess of 200 ft³ of compressed air.

3.3.4 Airline Respirator. See 3.3.14, *Supplied Air Respirator (SAR)*.

3.3.5 Atmosphere-Supplying Respirator. A respirator that supplies the respirator user with breathing air from a source independent of the ambient atmosphere; includes self-contained breathing apparatus (SCBA) and supplied air respirators (SAR). [See also 3.3.13, *Self-Contained Breathing Apparatus (SCBA)*, and 3.3.14, *Supplied Air Respirator (SAR)*.]

3.3.6 Breathing Air. See 3.3.8, *Compressed Breathing Air*.

3.3.7* Breathing Air System. A complete assembly of equipment to compress, store, and deliver breathing air for the filling of respirator breathing air cylinders.

3.3.8 Compressed Breathing Air. A respirable gas mixture derived from either normal atmospheric air or from manufactured synthetic air, stored in a compressed state in storage cylinders and respirator breathing air cylinders, and supplied to the user in a gaseous form. (See also 3.3.15, *Synthetic Breathing Air*.)

3.3.9* Organization. The entity that provides the direct management and supervision for the emergency incident response personnel.

3.3.10 ppm. Parts per million, volume per volume.

3.3.11 SAR. An abbreviation for supplied air respirator. [See also 3.3.14, *Supplied Air Respirator (SAR)*.]

3.3.12 SCBA. An abbreviation for self-contained breathing apparatus. [See also 3.3.13, *Self-Contained Breathing Apparatus (SCBA)*.]

3.3.13* Self-Contained Breathing Apparatus (SCBA). An atmosphere-supplying respirator that supplies a respirable air atmosphere to the user from a breathing air source that is independent of the ambient environment and designed to be carried by the user.

3.3.14 Supplied Air Respirator (SAR). An atmosphere-supplying respirator for which the source of the breathing air is not designed to be carried by the user. Also known as an “airline respirator.”

3.3.15 Synthetic Breathing Air. A manufactured breathing air that is produced by blending nitrogen and oxygen. (See also 3.3.8, *Compressed Breathing Air*.)

Chapter 4 Accreditation

4.1 General.

4.1.1 All breathing air quality verification testing as specified in Chapters 5 and 6 shall be performed by a laboratory that is accredited for testing compressed breathing air by an accreditation body in accordance with ISO 17025, *General requirements for the competence of calibration and testing laboratories*.

4.1.2 The accreditation body shall meet the requirements for an accreditation program specified in Section 4.2 of this chapter.



4.2 Accreditation Program.

4.2.1 The accreditation body shall not be owned or controlled by manufacturers or vendors of equipment related to the laboratory being accredited.

4.2.2 For accreditation, laboratory facilities and equipment for conducting proper tests shall be available.

4.2.3 The accreditation body shall ensure that the laboratory has a written program for calibrating all instruments and devices used for measurement.

4.2.4 The accreditation program procedures shall be used to ensure proper control of all testing.

4.2.5 The accreditation body shall ensure that the laboratory follows good laboratory practice regarding use of laboratory manuals, form data sheets, documentation of calibration and calibration routines, performance verification, proficiency testing, and staff qualification and training programs.

4.2.6 The accreditation certificate shall state the scope of accreditation.

Chapter 5 Air Quality Requirements

5.1 Regular Periodic Testing.

5.1.1* At least quarterly, the organization shall take breathing air samples and shall submit such samples to an accredited testing laboratory that meets the requirements specified in Chapter 4.

5.1.2 Breathing air samples shall be submitted to an accredited testing laboratory that meets the requirements specified in Chapter 4 whenever contamination of the compressed breathing air system, the stored compressed breathing air, or breathing air in an SCBA breathing air cylinder is suspected.

5.1.3 The accredited testing laboratory shall test the samples for breathing air quality levels as specified in Section 5.6.

5.1.4* The organization shall maintain documentation from the accredited testing laboratory of the results of all air sample tests for a period of not less than five (5) years.

5.2 Special Testing and Procedures for Maintenance Conditions.

5.2.1 When breathing air contamination could occur, breathing air samples shall be taken after any event including, but not limited to, alterations, maintenance, repairs, or relocation of any breathing air system or system part. Passing test results shall be received before returning the air compressor to service.

5.2.1.1* Prior to and after replacement of air purification filters, a breathing air sample shall be taken for testing. The "prior" sample shall be taken within 1 week before filter replacement. The air compressor shall be permitted to remain in service while awaiting test results.

5.2.1.1.1 The failure to obtain a breathing air sample before replacement of air purification filters as specified in 5.2.1.1 shall require the compressor to remain out of service until passing test results are achieved.

5.2.1.2 Breathing air samples taken for testing shall be submitted to an accredited testing laboratory that meets the requirements specified in Chapter 4.

5.2.2 The accredited testing laboratory shall test the samples for breathing air quality levels as specified in Section 5.6.

5.2.3* The organization shall maintain documentation from the accredited testing laboratory of the results of all air sample tests for a period of not less than five (5) years.

5.3* Special Testing and Procedures for Synthetic Breathing Air.

5.3.1 The organization shall document whether the breathing air is derived from normal atmospheric air or manufactured synthetic air.

5.3.2 Where the breathing air supply is synthetic breathing air, in addition to the quarterly testing specified in 5.1.1, air samples from each and every cylinder of synthetic breathing air shall be tested for oxygen content as specified in Section 6.1 of this standard. A supplier's analysis or certificate of oxygen content *shall not be sufficient* to comply with this requirement.

5.3.3 This testing shall occur when the organization takes delivery of a cylinder(s) of synthetic breathing air from a supplier or blends its own synthetic breathing air. The testing shall take place prior to filling any SCBA breathing air cylinders from the newly received synthetic breathing air supply.

5.3.4 The organization shall have the synthetic breathing air samples tested as specified in Section 6.1 of this standard to verify the oxygen content is not less than 19.5 percent and not greater than 23.5 percent by volume. A supplier's analysis or certificate of oxygen content *shall not be sufficient* to comply with this requirement.

5.3.5 Where any synthetic breathing air sample fails to comply with the breathing air quality requirements specified in 5.3.4, the organization shall reject the container and the synthetic breathing air shall not be used.

5.3.6 The organization shall have the synthetic breathing air tested for oxygen content as specified in 5.3.1 by an accredited testing laboratory that meets the requirements specified in Chapter 4.

5.3.7* The organization shall maintain documentation from the accredited testing laboratory of the results of all air sample tests for a period of not less than five (5) years.

5.4* Special Testing and Procedures for Contaminated Compressed Breathing Air.

5.4.1 Where any breathing air sample fails to comply with the breathing air quality requirements specified in Section 5.6, the organization shall remove from service the compressed breathing air system or stored breathing air system from which the sample was taken, shall determine the cause of the failure, and shall take corrective action.

5.4.1.1 Stored breathing air filled from a compressor that failed an air quality test shall be sampled, or replaced and sampled.

5.4.2 Any compressed breathing air system or stored breathing air system that has been removed from service according to 5.4.1 shall not be returned to service until a compressed breathing air sample has been submitted to an accredited testing laboratory for analysis according to Section 5.6, and found to pass the breathing air quality requirements.

5.4.2.1 All air storage cylinders and receivers shall be purged of any stored contaminated air, filled with air from a compressor system with air meeting this standard, and tested to the requirements of Section 5.6 prior to being placed back into service.

5.4.3 The accredited testing laboratory shall test the samples for breathing air quality levels as specified in Section 5.6.

5.4.4* The organization shall maintain documentation from the accredited testing laboratory of the results of all air sample tests for a period of not less than five (5) years.

5.4.5 The organization shall maintain documentation of actions taken to correct the problem for a period of not less than five (5) years.

5.5 Air Samples.

5.5.1* The quarterly breathing air sample shall be obtained directly at the point of air transfer from the breathing air system. The point of air transfer shall be any CGA 346/347 or SCBA-specific connection where breathing air cylinders are filled.

5.5.1.1 Stand-alone air storage cylinders filled from a compressor meeting the air quality requirements in Section 5.6 of this standard shall not require a quarterly sample.

5.5.2* When changing the breathing air system's purification components, two air samples shall be taken as required by 5.2.1.1.

5.5.2.1 One air sample shall be taken before changing the purification components, and the second air sample shall be taken after changing the purification components.

5.5.2.2 Air samples shall be taken downstream from purification components and prior to or bypassing any air storage DOT cylinders or ASME receivers if mechanically possible.

5.5.2.3* When system design does not allow for sampling per 5.5.2.2, all storage shall be drained and samples shall then be taken from the closest CGA 346/347 or SCBA-specific connection.

5.5.3* Compressed breathing air shall be allowed to flow through the fill hose for at least 1 minute prior to collecting the sample, only when the fill whip connection fitting is visibly free of foreign material, such as oil, particulate, and water. The sample shall be collected.

5.5.4 Where sampling apparatus cannot be operated correctly inside of the containment fill station, a remote fill hose or designated air sampling port shall be permitted to be used instead of the containment fill station.

5.5.5 Synthetic breathing air shall not be used until the oxygen content is tested and found to meet the requirements specified in Section 5.3.

5.5.5.1 The organization using the synthetic breathing air shall test or have a third party test each delivery container for its oxygen content. A supplier's analysis or certificate shall not be sufficient to meet this requirement.

5.5.5.2 Where the organization blends its own synthetic breathing air, the oxygen content of the synthetic breathing air in each mixing container shall be tested. This requirement shall be in addition to the regular periodic laboratory testing required by Section 5.1 of this chapter.

5.6* Breathing Air Quality Requirements.

5.6.1 Breathing air shall be tested for oxygen content as specified in Section 6.1, Oxygen Content Test, and shall have an oxygen content not less than 19.5 percent and not greater than 23.5 percent by volume.

5.6.2* Breathing air shall be tested for carbon monoxide content as specified in Section 6.2, Carbon Monoxide Content Test, and shall not have a concentration of carbon monoxide exceeding 5.0 ppm by volume.

5.6.3* Breathing air shall be tested for carbon dioxide content as specified in Section 6.3, Carbon Dioxide Content Test, and shall not have a concentration of carbon dioxide exceeding 1000 ppm by volume.

5.6.4 Breathing air shall be tested for condensed oil and particulate content as specified in Section 6.4, Condensed Oil and Particulate Content Test, and shall not have a concentration of condensed oil and particulate exceeding 2.0 mg/m³ at 22°C (72°F) and 760 mm (30 in.) of Hg.

5.6.5* Where breathing air supply for respirators is stored at pressures exceeding 15 bar (200 psi), the breathing air shall be tested for water content as specified in Section 6.5, Water Concentration Test, and shall not have a concentration of water exceeding 24 ppm by volume.

5.6.6 Breathing air shall be tested for nonmethane volatile organic compounds (VOCs) content as specified in Section 6.6, Hydrocarbon Content Test, and shall not have a nonmethane VOCs content exceeding 25 ppm as methane equivalents.

5.6.7* Breathing air shall be tested for odor as specified in Section 6.7, Determination of Odor Test, and shall not have a pronounced or unusual odor.

5.6.8 Breathing air shall be tested for nitrogen content as specified in Section 6.8, Nitrogen Content Test, and the concentration of nitrogen shall be not less than 75 percent and not greater than 81 percent.

5.7 Posting Requirements.

5.7.1 The accredited testing laboratory shall provide quality assurance signage for all breathing air systems utilized by the AHJ.

5.7.2 All worded portions of the sign shall be at least in English.

5.7.2.1 The quality assurance sign shall bear the following compliance statement legibly printed, and all letters and numbers shall be at least 25 mm (1 in.) in height:

**“THIS BREATHING AIR HAS BEEN TESTED TO
THE REQUIREMENTS OF NFPA 1989, 2013
EDITION.”**

5.7.2.2 The quality assurance sign shall also state the following, and all letters and numbers shall be at least 12 mm (½ in.) in height:

**“COMPRESSED AIR SOURCE IDENTIFICATION —
NEXT SAMPLE DUE ON OR BEFORE [date]”**

5.7.3* The authority having jurisdiction (AHJ) shall post the quality assurance signage in a conspicuous location within 6 ft of the compressor and/or any storage cylinders used to recharge emergency services SCBA or as a supplied air source.

Chapter 6 Test Methods

6.1 Oxygen Content Test.

6.1.1 Breathing air samples shall be obtained as specified in Section 5.5 of this standard.



6.1.2* The oxygen content shall be determined by any instrument that can demonstrate an accuracy of ± 0.5 percent oxygen in the presence of nitrogen and argon normally found in ambient air.

6.1.3 Calibration standards containing the applicable gaseous components to an accuracy of ± 2 percent relative shall be required to calibrate the analytical instruments used to determine the limiting characteristics of the breathing air.

6.1.4 Instrument calibration shall be conducted daily prior to sample analysis and confirmed at least every 10 air samples analyzed thereafter.

6.1.5 Analytical equipment shall be operated and properly calibrated in accordance with the manufacturer's instructions.

6.1.6 The percent oxygen content of the air sample shall be recorded and reported.

6.1.7 Pass or fail performance shall be determined in accordance with 5.6.1 and shall be recorded and reported.

6.2 Carbon Monoxide Content Test.

6.2.1 Breathing air samples shall be obtained as specified in Section 5.5 of this standard.

6.2.2* The carbon monoxide content shall be determined by any instrument that can demonstrate a minimum detection limit of 0.5 ppm or less and has a minimum accuracy of ± 0.5 ppm at 5 ppm.

6.2.3 Calibration standards containing the applicable gaseous components to an accuracy of ± 2 percent relative shall be required to calibrate the analytical instruments used to determine the limiting characteristics of the breathing air.

6.2.4 Instrument calibration shall be conducted daily prior to sample analysis and confirmed at least every 10 air samples analyzed thereafter.

6.2.5 Analytical equipment shall be operated and properly calibrated in accordance with the manufacturer's instructions.

6.2.6 The carbon monoxide content of the air sample shall be recorded and reported.

6.2.7 Pass or fail performance shall be determined in accordance with 5.6.2 and shall be recorded and reported.

6.3 Carbon Dioxide Content Test.

6.3.1 Breathing air samples shall be obtained as specified in Section 5.5 of this standard.

6.3.2* The carbon dioxide content shall be determined by any instrument that can demonstrate a minimum detection limit not exceeding 100 ppm and has a minimum accuracy of ± 50 ppm at 1000 ppm.

6.3.3 Calibration standards containing the applicable gaseous components to an accuracy of ± 2 percent relative shall be required to calibrate the analytical instruments used to determine the limiting characteristics of the breathing air.

6.3.4 Instrument calibration shall be conducted daily prior to sample analysis and confirmed at least every 10 air samples analyzed thereafter.

6.3.5 Analytical equipment shall be operated and properly calibrated in accordance with the manufacturer's instructions.

6.3.6 The carbon dioxide content of the air sample shall be recorded and reported.

6.3.7 Pass or fail performance shall be determined in accordance with 5.6.3 and shall be recorded and reported.

6.4 Condensed Oil and Particulate Content Test.

6.4.1 Breathing air samples shall be obtained as specified in Section 5.5 of this standard.

6.4.2 The sample for the condensed oil and particulate content shall be collected at a flow rate that would not result in an underestimation of the actual concentration.

6.4.3 Calibration standards with an accuracy of ± 2 percent relative shall be required to calibrate the analytical instruments used to determine the limiting characteristics of the breathing air.

6.4.4 Instrument calibration shall be conducted daily prior to sample analysis and confirmed at least every 10 air samples analyzed thereafter.

6.4.5 Condensed oil and particulate content shall be determined by passing at least 500 L of air through a preweighed, dry filter meeting the requirements of 6.4.6 and contained in a suitable holder. The filter shall be sized to capture and retain the condensed oil and particulate at the flow rate required in 6.4.2.

6.4.6 The filter shall provide 99.8 percent dioctyl phthalate (DOP) retention at 0.3 microns with a flow of 32 L/min through 100 cm² of media when measured in accordance with ASTM D 2986, *Standard Practice for Evaluation of Air Assay Media by the Monodisperse DOP (Dioctyl Phthalate) Smoke Test*.

6.4.7 The amount of air passing through the filter shall be determined by passing the air through the filter at a known flow rate and measuring the length of time it takes for the air to flow through the filter.

6.4.8 The filter shall be placed in a desiccator for 8 hours at a temperature of $25^{\circ}\text{C} \pm 3^{\circ}\text{C}$ ($77^{\circ}\text{F} \pm 5^{\circ}\text{F}$) to remove moisture, and then shall be reweighed. Desiccation shall be permitted to be omitted if the calculated concentration of oil and particulate is less than twice the limit of detection enumerated in 6.4.11.

6.4.9 As an alternative to 6.4.7, the filter shall be permitted to be heated to 38°C (100°F) for 1 hour in an air circulating oven, cooled in a desiccator, and then reweighed. Desiccation shall be omitted if the calculated concentration of oil and particulate is less than twice the limit of detection enumerated in 6.4.11.

6.4.10 The mass gain of the filter shall be used to determine the mass of collected condensed oil and particulate and, along with the volume of air passed through the filter as determined in 6.4.2, to calculate the combined concentration of condensed oil and particulate in the air sample.

6.4.11 The procedures used for measuring condensed oil and particulate content shall demonstrate a minimum detection limit not exceeding 0.1 mg/m^3 and shall have an accuracy of $\pm 0.1 \text{ mg/m}^3$ at 1.0 mg/m^3 .

6.4.12 The condensed oil and particulate content of the air sample shall be recorded and reported as mg/m^3 .

6.4.13 Pass or fail performance shall be determined in accordance with 5.6.4 and shall be recorded and reported.

6.5 Water Concentration Test.

6.5.1 Breathing air samples shall be obtained as specified in Section 5.5 of this standard.

6.5.2* The procedure for determining water concentration shall have a minimum detection limit not exceeding 3 ppm and shall have an accuracy of ± 8 ppm at the specified limit of 24 ppm.

6.5.3 Analytical equipment shall be operated and properly calibrated in accordance with the manufacturer's instructions.

6.5.4 The water content of the air sample shall be recorded and reported in ppm.

6.5.5 Pass or fail performance shall be determined in accordance with 5.6.5 and shall be recorded and reported.

6.6 Hydrocarbon Content Test.

6.6.1 Breathing air samples shall be obtained as specified in Section 5.5 of this standard.

6.6.2* The total nonmethane volatile organic compounds content, as methane equivalents, shall be determined by any instrument with a detection limit not exceeding 1.0 ppm and shall have a minimum accuracy of ± 1.0 ppm at 25 ppm.

6.6.3 The total nonmethane volatile hydrocarbon content, as methane equivalents, for this test method shall be defined as the single carbon atom equivalent.

6.6.4 Calibration standards containing the applicable gaseous components to an accuracy of ± 2 percent relative shall be required to calibrate the analytical instruments used to determine the limiting characteristics of the breathing air.

6.6.5 Instrument calibration shall be conducted daily prior to sample analysis and confirmed at least every 10 air samples analyzed thereafter.

6.6.6 Analytical equipment shall be operated and properly calibrated in accordance with the manufacturer's instructions.

6.6.7* The total nonmethane volatile organic compounds content of the air sample shall be recorded and reported.

6.6.8 Pass or fail performance shall be determined in accordance with 5.6.6 and shall be reported.

6.7 Determination of Odor Test.

6.7.1 Breathing air samples shall be obtained as specified in Section 5.5 of this standard.

6.7.2 Odor shall be determined by having persons conducting the test sniff a moderate flow of air from the container being tested.

6.7.3 Persons conducting the test shall not place their faces directly in front of the valve, but instead shall use a hand to direct toward the nose some of the gas being vented.

6.7.4 The disposition of the odor of the air sample shall be recorded and reported as "no/slight odor" or "pronounced or unusual odor."

6.7.5 Pass or fail performance shall be determined in accordance with 5.6.7 and shall be reported.

6.8 Nitrogen Content Test.

6.8.1 The nitrogen content shall be determined by any instrument that can demonstrate an accuracy of ± 0.5 percent.

6.8.2 A calibration standard containing the applicable gaseous components to an accuracy of ± 2 percent relative shall be required to calibrate the analytical instruments used to determine the limiting characteristics of the breathing air.

6.8.3 Instrument calibration shall be conducted daily prior to sample analysis and confirmed at least every 10 air samples analyzed thereafter.

6.8.4 Analytical equipment shall be operated and properly calibrated in accordance with the manufacturer's instructions.

6.8.5 The nitrogen content of the air sample shall be recorded and reported.

6.8.6 Where the air being tested is synthetic air, the pass or fail performance shall be determined in accordance with 5.6.8 and shall be recorded and reported.

Chapter 7 Compressed Breathing Air Systems

7.1 Installation.

7.1.1 Where a breathing air compressor is used to supply the breathing air system, the breathing air compressor shall be installed, operated, and maintained in accordance with the compressor manufacturer's instructions.

7.1.2 The breathing air system air intake shall be located to minimize the introduction of contaminants into the system.

7.1.3 A sign or placard shall be posted near the air intake identifying it as an intake source for breathing air.

7.1.4 Purification cartridges shall be properly installed in the correct sequence, as specified by the cartridge manufacturer's instructions.

7.1.5 The system shall not be installed in a manner that would permit the compressed air stream to bypass one or more of the air purifying components.

7.1.6 A breathing air system that uses a flexible line to supply air to an SCBA cylinder outside of containment or to a storage cylinder/cascade system shall have an indicating desiccant dryer installed at the discharge end of that line.

7.1.6.1 The required quarterly air sample as specified in 5.1.1 shall not be taken downstream of this extra dryer.

7.2 Compressors.

7.2.1 Oil-lubricated compressors shall be equipped with a tamperproof carbon monoxide (CO) monitor with audible and visual alarms that shall shut down the compressor when the CO level exceeds 5.0 ppm, and shall have a resolution of at least a 1 ppm.

7.2.1.1 The CO monitor shall have a limit of detection of 1.0 ppm and shall have a resolution of at least 1 ppm.

7.2.1.2* The CO monitor shall be equipped with a user-operated calibration system.

7.2.1.3 The CO calibration system shall include calibration gas to be used when calibrating the system in accordance with the compressor manufacturer's instructions.

7.2.2 Oil-lubricated compressors shall be equipped with a tamperproof, audible, high temperature alarm that shall shut down the compressor at the temperature specified by the compressor manufacturer.

7.2.3 Oil-lubricated compressors shall be equipped with a tamperproof low oil level, low oil pressure, or both low oil level and low oil pressure audible and visual alarm that shall shut



down the compressor if the oil level or the oil pressure drops below the limit specified by the compressor manufacturer.

7.2.4 All alarm activations shall be investigated and corrective action shall be taken before filling any cascade systems or SCBA breathing air cylinders.

7.3 Maintenance.

7.3.1 The breathing air system compressor shall be operated not less than 30 minutes each week, resulting in at least two condensate drain cycles.

7.3.2 The purification components of the breathing air system shall be replaced in accordance with the purification component manufacturer's instructions.

7.3.3 Compressed breathing air stored in steel cylinders or steel receivers of the breathing air system shall be replaced at least annually.

7.3.4 A positive pressure shall be maintained in depleted breathing air system cylinders and receivers until they are filled, to prevent the possibility of external contamination and condensation entering the cylinder or receiver.

7.4 Records.

7.4.1 The organization shall require that all air quality test results include the name of the testing lab's accrediting body and the lab's current designation by that body.

7.4.2 The organization shall maintain records of at least installation, maintenance, purification component changes, operation, trouble reports, and corrective actions taken.

7.4.3 The organization shall maintain records of air quality test results of compressed breathing air sources and air quality test results of the compressed breathing air produced or purchased.

7.4.4 The organization shall maintain records of all SCBA breathing air cylinder fills, and all breathing air system storage cylinder and receiver fills other than those storage cylinders and receivers that are connected to breathing air compressors.

7.4.4.1* These records shall include, but not be limited to, the fill date identification of the person performing the fill, cylinder serial number, breathing air source, final cylinder pressure, and most recent hydrostatic test date.

7.4.4.2 The organization shall maintain these records for a period of not less than five (5) years.

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.1 This standard sets criteria for breathing air quality for emergency services personnel who use atmospheric-supplying respirators and who perform their functions at high work levels during operations in hazardous and hostile environments. Other breathing air quality standards are focused on general industry and do not address emergency services needs.

A.3.3.7 Breathing Air System. The breathing air system components can include, but are not limited to, compressors, air purification systems, pressure regulators, safety devices, manifolds, cylinders and receivers, and interconnected piping.

A.3.3.9 Organization. Examples of such entities include, but are not limited to, fire departments, police departments, rescue squads, emergency medical service providers, and hazardous materials response teams.

A.3.3.13 Self-Contained Breathing Apparatus (SCBA). For the purposes of this standard, where the term is used without a qualifier, it indicates only open-circuit self-contained breathing apparatus or combination SCBA/SARs. For the purposes of this standard, combination SCBA/SAR are encompassed by the terms *self-contained breathing apparatus* or *SCBA*.

A.5.1.1 All compressed breathing air samples submitted to an accredited testing laboratory should be accompanied by a document specifying the following:

- (1) Name, address, and telephone number of the organization
- (2) Date the compressed breathing air sample was collected
- (3) Location point in the compressed breathing air system from which the compressed breathing air was sampled
- (4) Highest pressure at which the compressed breathing air is stored or used
- (5) Lowest temperature to which the compressed breathing air system or SCBA is exposed at any time during the year
- (6) Number of operating hours since the purification component(s) were installed
- (7) Brand, model, serial number, maximum rated operating pressure, actual operating pressure, maximum rated flow rate (L/min) at the maximum rated operating pressure, type of lubrication, purification components (e.g., mechanical separator, water vapor desiccant, activated charcoal, catalytic converter, particulate filter), order of the purification components in series with the compressor, and alarms (e.g., carbon monoxide alarm, high temperature alarm, low oil pressure alarm)
- (8) Brand, model, serial number, maximum rated operating pressure, actual operating pressure, maximum rated flow rate (L/min) at the maximum rated operating pressure, and actual flow rate of the compressor used to produce the compressed breathing air

A.5.1.4 Some records and reports can be created and stored electronically, whereas other items, such as forms, notices, stickers, and tags, are only practical and effective if tangible.

A.5.2.1.1 The purpose of the air sample taken after changing the filters is to verify that compressed breathing air is being produced that meets this standard. This test should be expected to give the best possible results because the filters are new, but it does not guarantee that the system will continue to produce good air until the next scheduled filter change. If tests are taken only after filter changes, it is possible for a problem in the system to go undetected. The purpose of taking a sample before changing the filters is to determine if the system has been producing compressed breathing air meeting this standard for the period since the last air test.

A.5.2.3 See A.5.1.4.

A.5.3 Synthetic breathing air is produced by mixing pure oxygen with pure nitrogen to produce a product that has the correct percentage of each for breathing. The actual procedure used to do this varies from supplier to supplier. One of the most common procedures is to attach all the breathing air cylinders to be filled to a manifold, then open the cylinder valves and add nitrogen into all of the cylinders. Once the appropriate pressure has been reached, the cylinder valves are

closed and the manifold is switched to oxygen. The cylinder valves are then reopened and oxygen is added to reach the final full cylinder pressure.

This and other procedures used to do the mixing are subject to human error and mechanical failure (e.g., a valve fails to open properly). These errors or failures can result in some cylinders of a “lot” receiving little or no oxygen. Such a cylinder can render an individual unconscious in a matter of seconds with almost no warning and can lead to death in minutes. It is also possible that a cylinder of pure oxygen could be delivered; although not necessarily dangerous to breathe, pure oxygen could be very hazardous in a fire-fighting situation.

Although synthetic breathing air is usually very clean and free of contaminants, it is potentially dangerous and should only be used where the end user can verify the oxygen content of each cylinder (not each “lot”) supplied. The use of synthetic breathing air has resulted in deaths, even though the cylinders involved were from “lots” that had been tested by the supplier. For this reason, the organization using synthetic breathing air is required to test, or to have a third party test, each delivery container for its oxygen content, and not depend on the supplier’s tests.

A.5.3.7 See A.5.1.4.

A.5.4 In the event of an emergency services personnel death, or if they become unconscious, or suffer a heart attack within 24 hours of using compressed breathing air, chain-of-custody procedures should be instituted, the respirator secured, the valve closed, and the respirator tagged and submitted to an accredited testing laboratory for analysis, as prescribed in Section 5.6.

A.5.4.4 See A.5.1.4.

A.5.5.1 The purpose of quarterly breathing air sampling is to verify that SCBAs are filled with air compliant with Section 5.6.

A.5.5.2 The purpose of taking air samples before and after changing the filters is to verify that the compressor is producing compressed breathing air that meets the requirements in Section 5.6. The sample taken prior to filter change is to verify that the compressor has continued to produce safe quality air since the last time stored air was tested. If this sample fails to meet air quality standards, then further investigation, purging of cylinders/receivers, and repeat testing is required. The sample taken prior to filter change can qualify as a quarterly sample if storage is permanently attached to the compressor. The sample taken after changing the filters is to verify that work performed has not adversely affected the quality of the air.

A.5.5.2.3 For breathing air systems that cannot bypass storage for testing, stored air should be drained to verify that the compressor maintenance did not adversely affect the quality of air.

A.5.5.3 Allowing compressed breathing air to flow through a fill hose that is less than or equal to 10 ft in length for 1 minute will purge the hose of room air and contaminants. Rubber and other polymeric materials will slowly pass water vapor through their structure by the process of permeation. The amount of water vapor that passes through under a given set of conditions is a function of the surface area of the polymeric material involved. This means a longer length of hose will admit more water vapor into the air stream than a shorter length of hose and could result in moisture levels above the requirements of this standard. Therefore, using long lengths of hose (longer than 10 ft) should be minimized. If longer lengths of hose are

needed, the hose should be stored with dry air inside and not open to the atmosphere, which contains significant amounts of moisture. Dry air in a stored hose should be stored at a gauge pressure between 25 psi and 100 psi. High pressure is not required and could be dangerous.

A.5.6 This standard sets criteria for breathing air quality for emergency services personnel who use atmospheric-supplying respirators and who perform their functions at high work levels during operations in hazardous and hostile environments. Other breathing air quality standards are focused on general industry and do not address emergency services needs.

A.5.6.2 The percent carboxyhemoglobin (%COHb) level of nonsmoking emergency services personnel doing heavy work while breathing air containing 5.0 ppm of carbon monoxide (CO) could rise to 3.5 percent. This is the biological exposure index (BEI) for COHb established by the American Conference of Government Industrial Hygienists (ACGIH). This represents a level below which nearly all workers should not experience adverse health effects.

A.5.6.3 Carbon dioxide levels higher than 500 ppm should be investigated.

A.5.6.5 Excessive moisture content in compressed breathing air can render the purification system ineffective in removing contaminants, lead to corrosion in the compressed breathing air system, and result in condensation of water with subsequent freeze-up of the SCBA regulator and blockage of air flow to the face piece.

A.5.6.7 Specific measurement of odor in gaseous air is impractical. Air normally can have a slight odor, but should not have a pronounced or unusual odor.

A.5.7.3 Stored compressed breathing air should be replaced at least annually.

A.6.1.2 Breathing air normally has approximately 78 percent nitrogen, 21 percent oxygen, and 1 percent argon. Suggested analytical procedures for determination of oxygen concentration are as follows:

- (1) A paramagnetic-type analyzer calibrated (zeroed and spanned) at appropriate intervals by the use of calibration gas standards using nitrogen as the base gas.
- (2) An electrochemical-type analyzer containing a solid or aqueous electrolyte. The electrochemical-type analyzer should be calibrated at appropriate intervals by the use of calibration gas standards.
- (3) A thermal conductivity-type analyzer calibrated at appropriate intervals by the use of calibration gas standards using nitrogen as the base gas.
- (4) A gas chromatograph capable of separating and detecting oxygen in nitrogen. The system should be able to distinguish oxygen from argon when testing atmospheric air. The system should be calibrated by the use of calibration gas standards containing an appropriate known amount of oxygen.

A.6.2.2 Suggested analytical procedures for determination of carbon monoxide concentration are as follows:

- (1) A gas cell equipped infrared gas analyzer should be calibrated at appropriate intervals by the use of calibration gas standards at a wavelength of approximately 4.6 microns. *It should be noted that the accuracy of this method is relatively poor at these levels.*



- (2) An electrochemical cell analyzer that is specific for carbon monoxide should be calibrated at appropriate intervals by the use of calibration gas standards.
- (3) A catalytic methanator gas chromatograph should be calibrated at appropriate intervals by the use of calibration gas standards.
- (4) The gas chromatograph technique utilized should be specific for the separation and analysis of carbon monoxide. Appropriate impurity techniques should be permitted to be used to attain the sensitivity required in 6.2.2. The gas chromatograph should be calibrated at appropriate intervals by the use of calibration gas standards.

A.6.3.2 Suggested analytical procedures for determination of carbon dioxide concentration are as follows:

- (1) A gas cell equipped dispersive or nondispersive infrared analyzer should be calibrated at appropriate intervals by the use of calibration gas standards at a wavelength of approximately 4.3 microns.
- (2) A gas chromatograph should be capable of separating and detecting carbon dioxide. The gas chromatograph technique utilized should be specific for the separation and analysis of carbon dioxide. Appropriate impurity techniques should be used to attain the sensitivity required in 6.3.2. The gas chromatograph should be calibrated at appropriate intervals by the use of calibration gas standards.

A.6.5.2 Suggested analytical procedures for determination of water concentration are as follows:

- (1) An electrolytic hygrometer should have an indicator graduated in ppm (volume/volume) on a range that is no greater than 10 times the specified maximum moisture content.
- (2) With a dewpoint analyzer, the temperature of a viewed surface should be measured at the time formation of moisture condensation is first observed.
- (3) A piezoelectric sorption hygrometer should have a range that is no greater than 10 times the specified maximum moisture content.

- (4) A metal oxide capacitor equipped analyzer should have a range that is no greater than 10 times the specified maximum moisture content.
- (5) The gas chromatograph technique utilized should be specific to the separation and analysis of water content. Appropriate impurity techniques should be used to attain the sensitivity required in 6.5.2. The gas chromatograph should be calibrated at appropriate intervals by the use of calibration gas standards.

A.6.6.2 Suggested analytical procedures for determination of total nonmethane VOCs concentration are as follows:

- (1) A flame ionization-type analyzer should be calibrated at appropriate intervals by the use of calibration gas (air balance) standards. The range used should not be greater than 250 ppm.
- (2) A gas cell equipped dispersive or nondispersive infrared analyzer should be calibrated at appropriate intervals by the use of calibration gas standards at a wavelength of approximately 3.5 microns (the characteristic absorption wavelength for C-H stretching).
- (3) The gas chromatograph technique utilized should be specific to the separation and analysis of hydrocarbon content. Appropriate impurity techniques should be used to attain the sensitivity required in 6.6.2. The gas chromatograph should be calibrated at appropriate intervals by the use of calibration gas standards.

A.6.6.7 Where nonmethane volatile hydrocarbon contaminant exceeds 10 ppm, individual species should be identified and quantified.

A.7.2.1.2 Gas monitors must be periodically calibrated to ensure accuracy and repeatability. It is recommended that calibration of the CO monitor be done before each day's use for best results.

A.7.4.4.1 See Figure A.7.4.4.1, Breathing Air Cylinder Fill Log.

Annex B Informational References (Reserved)

BREATHING AIR CYLINDER FILL LOG <i>(Insert the Breathing Air Source)</i>				
Date	Name of Person Filling	Cylinder Serial Number	Final Cylinder PSI	Hydrostatic Test Date

© 2013 National Fire Protection Association

NFPA 1989

FIGURE A.7.4.4.1 Breathing Air Cylinder Fill Log.

Index

Copyright © 2013 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

-A-		-E-	
Accreditation Chap. 4		Explanatory Material Annex A	
Accreditation Program 4.2			
General 4.1		-I-	
Accreditation Body		Informational References (Reserved) Annex B	
Definition..... 3.3.2			
Accreditation/Accredited		-O-	
Definition..... 3.3.1		Organization	
Administration Chap. 1		Definition 3.3.9, A.3.3.9	
Application 1.3			
Purpose 1.2		-P-	
Scope..... 1.1, A.1.1		ppm	
Units 1.4		Definition 3.3.10	
Air Quality Requirements Chap. 5			
Air Samples 5.5		-R-	
Breathing Air Quality Requirements..... 5.6, A.5.6		Referenced Publications Chap. 2	
Posting Requirements 5.7		General 2.1	
Regular Periodic Testing 5.1		NFPA Publications 2.2	
Special Testing and Procedures for Contaminated		Other Publications..... 2.3	
Compressed Breathing Air..... 5.4, A.5.4		References for Extracts in Mandatory Sections. (Reserved) 2.4	
Special Testing and Procedures for Maintenance			
Conditions..... 5.2		-S-	
Special Testing and Procedures for Synthetic		SAR	
Breathing Air..... 5.3, A.5.3		Definition 3.3.11	
Air Storage		SCBA	
Definition..... 3.3.3		Definition 3.3.12	
Airline Respirator		Self-Contained Breathing Apparatus (SCBA)	
Definition..... 3.3.4		Definition..... 3.3.13, A.3.3.13	
Atmosphere-Supplying Respirator		Shall	
Definition..... 3.3.5		Definition..... 3.2.1	
		Should	
-B-		Definition..... 3.2.2	
Breathing Air		Standard	
Definition..... 3.3.6		Definition..... 3.2.3	
Breathing Air System		Supplied Air Respirator (SAR)	
Definition 3.3.7, A.3.3.7		Definition 3.3.14	
		Synthetic Breathing Air	
-C-		Definition 3.3.15	
Compressed Breathing Air		-T-	
Definition..... 3.3.8		Test Methods Chap. 6	
Compressed Breathing Air Systems Chap. 7		Carbon Dioxide Content Test 6.3	
Compressors..... 7.2		Carbon Monoxide Content Test..... 6.2	
Installation..... 7.1		Condensed Oil and Particulate Content Test 6.4	
Maintenance 7.3		Determination of Odor Test 6.7	
Records 7.4		Hydrocarbon Content Test 6.6	
		Nitrogen Content Test..... 6.8	
-D-		Oxygen Content Test 6.1	
Definitions Chap. 3		Water Concentration Test..... 6.5	

Sequence of Events Leading to Issuance of This NFPA Committee Document

Step 1: Call for Proposals

- Proposed new Document or new edition of an existing Document is entered into one of two yearly revision cycles, and a Call for Proposals is published.

Step 2: Report on Proposals (ROP)

- Committee meets to act on Proposals, to develop its own Proposals, and to prepare its Report.
- Committee votes by written ballot on Proposals. If two-thirds approve, Report goes forward. Lacking two-thirds approval, Report returns to Committee.
- Report on Proposals (ROP) is published for public review and comment.

Step 3: Report on Comments (ROC)

- Committee meets to act on Public Comments to develop its own Comments, and to prepare its report.
- Committee votes by written ballot on Comments. If two-thirds approve, Report goes forward. Lacking two-thirds approval, Report returns to Committee.
- Report on Comments (ROC) is published for public review.

Step 4: Technical Report Session

- “*Notices of intent to make a motion*” are filed, are reviewed, and valid motions are certified for presentation at the Technical Report Session. (“Consent Documents” that have no certified motions bypass the Technical Report Session and proceed to the Standards Council for issuance.)
- NFPA membership meets each June at the Annual Meeting Technical Report Session and acts on Technical Committee Reports (ROP and ROC) for Documents with “certified amending motions.”
- Committee(s) vote on any amendments to Report approved at NFPA Annual Membership Meeting.

Step 5: Standards Council Issuance

- Notification of intent to file an appeal to the Standards Council on Association action must be filed within 20 days of the NFPA Annual Membership Meeting.
- Standards Council decides, based on all evidence, whether or not to issue Document or to take other action, including hearing any appeals.

Committee Membership Classifications

The following classifications apply to Technical Committee members and represent their principal interest in the activity of the committee.

- M *Manufacturer:* A representative of a maker or marketer of a product, assembly, or system, or portion thereof, that is affected by the standard.
- U *User:* A representative of an entity that is subject to the provisions of the standard or that voluntarily uses the standard.
- I/M *Installer/Maintainer:* A representative of an entity that is in the business of installing or maintaining a product, assembly, or system affected by the standard.
- L *Labor:* A labor representative or employee concerned with safety in the workplace.
- R/T *Applied Research/Testing Laboratory:* A representative of an independent testing laboratory or independent applied research organization that promulgates and/or enforces standards.
- E *Enforcing Authority:* A representative of an agency or an organization that promulgates and/or enforces standards.
- I *Insurance:* A representative of an insurance company, broker, agent, bureau, or inspection agency.
- C *Consumer:* A person who is, or represents, the ultimate purchaser of a product, system, or service affected by the standard, but who is not included in the *User* classification.
- SE *Special Expert:* A person not representing any of the previous classifications, but who has a special expertise in the scope of the standard or portion thereof.

NOTES:

1. “Standard” connotes code, standard, recommended practice, or guide.
2. A representative includes an employee.
3. While these classifications will be used by the Standards Council to achieve a balance for Technical Committees, the Standards Council may determine that new classifications of members or unique interests need representation in order to foster the best possible committee deliberations on any project. In this connection, the Standards Council may make appointments as it deems appropriate in the public interest, such as the classification of “Utilities” in the National Electrical Code Committee.
4. Representatives of subsidiaries of any group are generally considered to have the same classification as the parent organization.