

NFPA 408

Standard for Aircraft Hand Portable Fire Extinguishers

2004 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
An International Codes and Standards Organization

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA DOCUMENTS

NFPA codes, standards, recommended practices, and guides, of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in its codes and standards.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the NFPA list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights asserted in connection with any items which are mentioned in or are the subject of NFPA codes, standards, recommended practices, and guides, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on these documents. Users of these documents are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

NFPA adheres to applicable policies of the American National Standards Institute with respect to patents. For further information contact the NFPA at the address listed below.

Law and Regulations

Users of these documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the NFPA. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making this document available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to this document.

Use of NFPA documents for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA codes, standards, recommended practices, and guides and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

For more information about NFPA, visit the NFPA website at www.nfpa.org.

Copyright © 2004, National Fire Protection Association, All Rights Reserved

NFPA 408
Standard for
Aircraft Hand Portable Fire Extinguishers
2004 Edition

This edition of NFPA 408, *Standard for Aircraft Hand Portable Fire Extinguishers*, was prepared by the Technical Committee on Aircraft Rescue and Fire Fighting and acted on by NFPA at its May Association Technical Meeting held May 23–26, 2004, in Salt Lake City, UT. It was issued by the Standards Council on July 16, 2004, with an effective date of August 5, 2004, and supersedes all previous editions.

This edition of NFPA 408 was approved as an American National Standard on August 5, 2004.

Origin and Development of NFPA 408

Work on this standard started in 1947 after requests were received by the National Fire Protection Association for recommendations on aircraft hand fire extinguishers. During the intervening years, prior to the adoption of the first draft of this text in 1955 by the Association, a number of proposals were prepared and circulated for comment and criticism. In 1956, a revision was adopted incorporating an appendix on air crew training. Revisions were made in 1964, 1965, 1970, and 1973.

The 1984 document was completely revised to recognize state-of-the-art developments in extinguishing agents and to bring the document into conformance with the NFPA *Manual of Style*.

The 1989 edition was a reconfirmation of the 1984 edition. The 1994 edition was a partial revision. The 1999 edition was a reconfirmation of the 1994 edition.

Minimum requirements have been added to the 2004 edition of the standard for halocarbon agent fire extinguishers as they are now acceptable for installation onboard aircraft, in lieu of halon extinguishers, per the U.S. Federal Aviation Administration (FAA).

Technical Committee on Aircraft Rescue and Fire Fighting

Brian Boucher, Chair
Air Canada Pilots Association, NY [L]

Lawrence V. Powers, Secretary
Massport Fire-Rescue, MA [L]

Keith W. Bagot, U.S. Federal Aviation Administration, NJ [RT]
Alan Black, Dallas/Fort Worth Airport Board, TX [C]
Rep. Airports Council International-North America
Ralph Colet, John Russo Industrial Inc., CA [M]
Robert L. Darwin, Hughes Associates, Inc., MD [SE]
Ross A. Davidson, U.S. Navy Air Warfare Center Weapons Division, CA [C]
Roger Davis, BAA PLC Heathrow Airport Ltd, England [C]
Christopher Farnaby, United Kingdom Civil Aviation Authority, England [E]
Kenneth R. Gilliam, U.S. Federal Aviation Administration, FL [E]
Donald E. Hilderbrand, Phoenix Fire Department, AZ [U]
L. M. Krasner, FM Global, MA [I]
Rep. FM Global/FM Research
Paul S. Meyer, Hartsfield Atlanta International Airport, GA [C]
John J. O'Sullivan, British Airways, PLC, England [SE]
Pam L. Phillips, Port Authority of New York and New Jersey, NY [C]
Rep. American Association of Airport Executives

Thomas J. Phillips, Airline Pilots Association, PA [L]
Danny M. Pierce, Los Angeles World Airports, CA [L]
Rep. International Aviation Fire Protection Association
Lee W. Prazer, Akron Brass Company, OH [M]
Richard M. Radford, Dubai International Airport, United Arab Emirates [U]
Michael D. Reagan, Los Angeles City Fire Department, CA [U]
Gary T. Schott, Omaha Airport Authority, NE [L]
Rep. Aircraft Rescue and Fire Fighting Working Group
John M. Schuster, 3M Company, MN [M]
Terry Seaborn, Oshkosh Truck Corporation, WI [M]
Robert L. Shaub, Emergency One, Incorporated, FL [M]
William D. Stewart, Maryland Aviation Administration, MD [U]
Rep. International Association of Fire Chiefs
Bernard Valois, Transport Canada Civil Aviation, Canada [E]
Joseph A. Wright, ARFF Technical Services, Incorporated, PA [SE]

Alternates

Tony Cash, United Kingdom Civil Authority, England [E]
(Alt. to C. Farnaby)
Michael P. Crowe, Oshkosh Truck Corporation, WI [M]
(Alt. to T. Seaborn)
Robert J. Donahue, Massport Fire-Rescue, MA [L]
(Alt. to L. V. Powers)
George F. Hall, U.S. Air Force-HQ AFCEA, FL [C]
(Vot. Alt. to U.S. Air Force-HQ AFCEA Rep.)
Dawn E. Lucini, Airports Council International-North America, DC [C]
(Alt. to A. Black)
Thomas V. Mai, U.S. Federal Aviation Administration, DC [E]
(Alt. to K. R. Gilliam)
Madhu Manikkam, Emergency One, Incorporated, FL [M]
(Alt. to R. L. Shaub)
Harold D. Miller, Atlanta Fire Department, GA [C]
(Alt. to P. S. Meyer)

Gaétan Morinville, Canadian Forces Fire Marshal 4, Canada [C]
(Vot. Alt. to Canadian Forces Fire Marshal Rep.)
James F. O'Regan, O'Regan Consulting/JRI, Incorporated, MA [M]
(Alt. to R. Colet)
William Savage, Gloucestershire, United Kingdom [L]
(Alt. to D. M. Pierce)
Joseph L. Scheffey, Hughes Associates, Incorporated, MD [SE]
(Alt. to R. L. Darwin)
Bernard Stone, BAA PLC Gatwick Airport, United Kingdom [C]
(Alt. to R. Davis)
Craig A. Williams, American Association of Airport Executives, VA [L]
(Alt. to T. J. Phillips)

Nonvoting

B. Victor Hewes, Airport Safety Services, GA [SE]
Thomas J. Lett, Albuquerque Fire and Safety Associates, NM [SE]

Francois Villard, Geneva, Vessy, Switzerland [SE]

Mark T. Conroy, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on aircraft rescue and fire-fighting services and equipment, for procedures for handling aircraft fire emergencies, and for specialized vehicles used to perform these functions at airports, with particular emphasis on saving lives and reducing injuries coincident with aircraft fires following impact or aircraft ground fires. This Committee also shall have responsibility for documents on aircraft hand fire extinguishers and accident prevention and the saving of lives in future aircraft accidents involving fire.

Contents

Chapter 1 Administration	408- 4	Chapter 5 Distribution of Extinguishers	408- 7
1.1 Scope	408- 4	5.1 Passenger Aircraft	408- 7
1.2 Purpose	408- 4	5.2 Cargo Aircraft	408- 8
Chapter 2 Referenced Publications	408- 4	5.3 Combi Aircraft	408- 8
2.1 General	408- 4	Chapter 6 Inspection, Maintenance, and	
2.2 NFPA Publication	408- 4	Hydrostatic Testing	408- 8
2.3 Other Publications	408- 4	6.1 Preflight Inspection	408- 8
Chapter 3 Definitions	408- 5	6.2 Maintenance	408- 8
3.1 General	408- 5	6.3 Hydrostatic Testing	408- 8
3.2 NFPA Official Definitions	408- 5	Chapter 7 Flight Crew Training	408- 8
3.3 General Definitions	408- 5	7.1 General	408- 8
Chapter 4 Types and Capacities	408- 6	7.2 Classroom/Fire Scenario Instruction	408- 8
4.1 General	408- 6	7.3 Manipulative Skills Training	408- 9
4.2 Water	408- 6	7.4 Combi Aircraft	408- 9
4.3 Halogenated Agents	408- 6	7.5 Recurrent Training and Testing	408- 9
4.4 Carbon Dioxide	408- 6	Annex A Explanatory Material	408- 9
4.5 Dry Chemical	408- 6	Annex B Informational References	408-11
4.6 Dry Powder	408- 7	Index	408-12
4.7 Other Agents	408- 7		

NFPA 408

Standard for

Aircraft Hand Portable Fire Extinguishers

2004 Edition

IMPORTANT NOTE: *This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Documents." They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.*

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for mandatory extracts are given in Chapter 2 and those for nonmandatory extracts are given in Annex B. Editorial changes to extracted material consist of revising references to an appropriate division in this document or the inclusion of the document number with the division number when the reference is to the original document. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration

1.1 Scope. This standard specifies requirements for the type, capacity, rating, number, location, installation, and maintenance of aircraft hand portable fire extinguishers to be provided for the use of flight crew members or other occupants of an aircraft for the control of incipient fires in the areas of aircraft that are accessible during flight.

1.1.1 This standard also includes requirements for training flight crew members in the use of these extinguishers.

1.1.2 This standard does not cover fire detection and fixed fire-extinguishing systems installed in an aircraft or fire detection and fire-extinguishing systems for the protection of ground maintenance operations.

1.1.3 Specific protection for Class D fires and for fires in hazardous materials is beyond the scope of this standard.

1.2 Purpose. This standard is intended for use by those responsible for selecting, purchasing, installing, approving, and maintaining aircraft hand portable fire extinguishers and for those responsible for training personnel in their use.

1.2.1* The specific requirements established in this standard are intended for the particular environment of an aircraft where fire extinguishment must be the first priority.

1.2.2* Hand portable fire extinguishers, as specified in NFPA 10, have the general purpose of serving as first-aid fire-fighting appliances.

1.2.3 Accordingly, the requirements of Chapters 6 and 7 of NFPA 10 are applicable to the aviation environment and are supplemental to the specific requirements of this standard.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publication. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2002 edition.

2.3 Other Publications.

2.3.1 FAA Publication. Federal Aviation Administration, William J. Hughes Technical Center, Airport and Aircraft Safety, Research and Development Division, Atlantic City International Airport, NJ 08405.

DOT/FAA/AR-01/37, "Development of a Minimum Performance Standard for Hand-Held Fire Extinguishers as a Replacement for Halon 1211 on Civilian Transport Category Aircraft," August, 2002.

2.3.2 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

ANSI/UL 8, *Standard for Safety Foam Fire Extinguishers*, 1995.

ANSI/UL 154, *Standard for Safety Carbon Dioxide Fire Extinguishers*, 1995.

ANSI/UL 299, *Standard for Safety Dry Chemical Fire Extinguishers*, 2002.

ANSI/UL 626, *Standard for Safety 2½ Gallon Stored Pressure Water-Type Fire Extinguishers*, 1995.

ANSI/UL 711, *Standard for Rating and Fire Testing of Fire Extinguishers*, 2002.

ANSI/UL 1093, *Standard for Safety Halogenated Agent Fire Extinguishers*, 1995.

ANSI/UL 1803, *Standard for Safety Factory Follow-up on Third Party Certified Portable Fire Extinguishers*, 1994.

ANSI/UL 2129, *Standard for Safety for Halocarbon Clean Agent Fire Extinguishers*, 1999.

2.3.3 ULC Publications. Underwriters' Laboratories of Canada, 7 Underwriters Road, Toronto, Ontario M1R 3B4, Canada.

CAN/ULC-S503, *Standard for Carbon Dioxide Hand and Wheeled Fire Extinguishers*, 1997.

CAN/ULC-S504, *Standard for Dry Chemical and Dry Powder Hand and Wheeled Fire Extinguishers*, 1999.

CAN/ULC-S507, *Standard for 9 Litre Stored Pressure Water Type Fire Extinguishers*, 2001.

CAN/ULC-S508, *Standard for Rating and Fire Testing of Fire Extinguishers and Class D Extinguishing Media*, 1995.

CAN/ULC-S512, *Standard for Halogenated Agent Hand and Wheeled Fire Extinguishers*, 1997.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not included, common usage of the terms shall apply.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3 Labeled. Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

3.2.4* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

3.2.5 Shall. Indicates a mandatory requirement.

3.2.6 Should. Indicates a recommendation or that which is advised but not required.

3.2.7 Standard. A document, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and which is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions shall be located in an appendix or annex, footnote, or fine-print note and are not to be considered a part of the requirements of a standard.

3.3 General Definitions.

3.3.1 Aircraft.

3.3.1.1 Cargo Aircraft. An aircraft that is configured solely to carry cargo and no personnel other than the flight crew and any additional crew required for the care of the cargo.

3.3.1.2 Combi. An aircraft designed to transport both passengers and cargo on the same level within the fuselage. [402:3.3]

3.3.1.3 Passenger Aircraft. An aircraft designed for the primary function of carrying passengers.

3.3.2 Aircraft Hand Portable Fire Extinguisher. An approved, portable device that is carried and operated by hand and contains an extinguishing agent that can be expelled under pressure for the purpose of suppressing or extinguishing fire.

3.3.3 Bar. See 3.3.11, Galley.

3.3.4 Buffet. See 3.3.11, Galley.

3.3.5 Cargo/Baggage Compartment. An enclosed compartment within, or attached to, an aircraft fuselage that is separate from the passenger and flight crew areas and that is almost always accessible only from the exterior of the fuselage.

3.3.6 Cockpit. See 3.3.10, Flight Deck.

3.3.7 Extinguisher. See 3.3.2, Aircraft Hand Portable Fire Extinguisher.

3.3.8 Fire Classifications.

3.3.8.1* Class A Fires. Fires in ordinary combustible materials, such as wood, cloth, paper, rubber, and many plastics. [10:3.3]

3.3.8.2 Class B Fires. Fires in flammable liquids, combustible liquids, petroleum greases, tars, oils, oil-based paints, solvents, lacquers, alcohols, and flammable gases. [10:3.3]

3.3.8.3* Class C Fires. Fires that involve energized electrical equipment where the electrical nonconductivity of the extinguishing media is of importance.

3.3.8.4 Class D Fires. Fires in combustible metals, such as magnesium, titanium, zirconium, sodium, lithium, and potassium. [10:3.3]

3.3.9 Flight Crew. Members of the aircraft crew whose responsibilities include the operation and management of the aircraft flight controls, engine(s), and systems, including, but not limited to, pilot in command (captain), first officer (copilot), second officer (flight engineer).

3.3.10* Flight Deck. The area of the aircraft arranged for use of the pilot and flight crew operating the aircraft.

3.3.11* Galley. An area of an aircraft used for storing, refrigerating, heating, and dispensing food and beverages. [410:3.3]

3.3.12* Halogenated Agents. Halogenated agents referenced in this standard are either halons [i.e., bromotrifluoromethane (Halon 1301), bromochlorodifluoromethane (Halon 1211), and mixtures of Halon 1211 and Halon 1301 (Halon 1211/1301)] or halocarbon agents [i.e., hydrochlorofluorocarbon (HCFC), HFC (hydrofluorocarbon), or perfluorocarbon (PFC) based halogenated agents].

3.3.12.1 Halocarbon. A halogenated agent whose chemical name is inclusive of one or more of the following: hydrochlorofluorocarbon (HCFC), hydrofluorocarbon (HFC), or perfluorocarbon (PFC) based halogenated agents.

3.3.12.2* Halon 1211. A halogenated agent whose chemical name is bromochlorodifluoromethane (CBrClF_2) and that is a multipurpose Class ABC-rated agent effective against flammable liquid fires. [402:3.3]

3.3.12.3* Halon 1301. A halogenated agent whose chemical name is bromotrifluoromethane (CBrF_3) that is recognized as an agent having Class ABC capability in total flooding systems. [402:3.3]

3.3.13 Hand Fire Extinguisher. See 3.3.2, Aircraft Hand Portable Fire Extinguisher.

3.3.14* Maximum Certificated Occupant Capacity. The maximum number of persons that can be carried for each specific aircraft model as certified by the authority having jurisdiction.

3.3.15* Rated/Rating. A numerical value assigned to an extinguisher based on its fire-extinguishing capability.

Chapter 4 Types and Capacities

4.1 General.

4.1.1 Hand portable fire extinguishers shall meet or exceed all of the requirements of one of the fire test standards and one of the appropriate performance standards in 4.1.2.

4.1.2 Hand portable fire extinguishers used to comply with this standard shall be listed and labeled and meet or exceed all the requirements of one or more of the applicable fire test standards and one of the applicable performance standards as follows:

- (1) Fire test standards as follows:
 - (a) For halons, carbon dioxide, dry chemical, water, and film-forming foam (all solely), use ANSI/UL 711 and CAN/ULC-S508.
 - (b) For halocarbon types for civilian transport category aircraft, use DOT/FAA/AR-01/37.
- (2) Performance standards as follows:
 - (a) For carbon dioxide types, use ANSI/UL 154 and CAN/ULC-S503.
 - (b) For dry chemical types, use ANSI/UL 299 and CAN/ULC-S504.
 - (c) For water types, use ANSI/UL 626 and CAN/ULC-S507.
 - (d) For halon types, use ANSI/UL 1093 and CAN/ULC-S512.
 - (e) For film-forming foam types, use ANSI/UL 8.
 - (f) For halocarbon types, use ANSI/UL 2129.

4.1.3 Listing and Labeling Organization.

4.1.3.1 Identification of the listing and labeling organization, with ratings and classifications, including the performance standard that the extinguisher meets or exceeds, shall be marked on each extinguisher.

4.1.3.2 An organization that lists, labels, and marks extinguishers used to comply with the requirements of this standard shall utilize a third-party certification program for hand portable fire extinguishers that meets or exceeds the requirements of ANSI/UL 1803.

4.1.3.3 The requirement of 4.1.3.2 shall not apply to the following:

- (1) Extinguishers manufactured prior to January 1, 1989
- (2) Certification organizations accredited by the Standards Council of Canada

4.1.4* All aircraft hand portable fire extinguishers shall function as designed by the manufacturer at temperature ranges from -40°C to 49°C (-40°F to 120°F).

4.1.5* Water extinguishers that have a capacity of 2 L (0.53 gal) and that have special approval of the authority having jurisdiction shall not be required to be labeled and shall comply with 4.1.1, 4.1.2, 4.1.3, and 4.1.4.

4.2 Water.

4.2.1 Water-based extinguishers shall have a minimum rating of 1-A and shall be equipped with either a spray or straight stream nozzle.

4.2.2 Water-based extinguishers shall not be used on Class B, Class C, or Class D fires.

4.2.3 Cargo compartments shall have one or more water-based extinguishers with a minimum rating of 2-A.

4.3 Halogenated Agents.

4.3.1* General.

4.3.1.1 Halogenated agents specified in this standard shall be used in hand portable fire extinguishers in aircraft.

4.3.1.2 Halocarbon extinguishers shall be not less than the quantity required to achieve a 5-B:C rating and conform with the requirements specified in DOT/FAA/AR-01/37 (*see* 4.1.2).

4.3.2* Halon 1211 and Halocarbon Agent Extinguishers.

4.3.2.1 Occupied Spaces.

4.3.2.1.1* For occupied spaces on aircraft, Halon 1211 extinguishers shall be not less than 1.2 kg (2.5 lb) capacity nor more than 2.3 kg (5 lb) capacity.

4.3.2.1.1.1 The extinguishers specified in 4.3.2.1.1 shall have a minimum rating of 5-B:C, shall have not less than an 8-second effective discharge time, shall have not less than a 3 m (10 ft) liquid range, and shall be permitted to be equipped with a discharge hose.

4.3.2.1.2* For occupied spaces on small aircraft only, with a maximum certificated occupant capacity of one to four persons including the pilot, a Halon 1211 extinguisher with a minimum rating of 2-B:C, or a halocarbon extinguisher that does not exceed the exposures observed for Halon 1211, shall be permitted to be used as an option to the Halon 1301 extinguishers specified in Table 5.1.1.

4.3.2.2 For accessible cargo compartments of Combi aircraft and cargo aircraft, Halon 1211 extinguishers shall be not less than 5.9 kg (13 lb) capacity and shall have a minimum rating of 2-A:40-B:C.

4.3.2.2.1 Halocarbon extinguishers with an equivalent minimum rating shall be permitted in the application outlined in 4.3.2.2.

4.3.2.3 The total Halon 1211 agent available in all extinguishers in any single compartment, if discharged simultaneously, shall be capable of producing a concentration not greater than 2 percent by volume at 49°C (120°F) in the compartment.

4.3.2.3.1 Halocarbon extinguisher toxicity has been demonstrated by Federal Aviation Administration (FAA) modeling and test procedures to be no greater based on quantities discharged of the products that meet the requirements for fire test standards ANSI/UL 711 and DOT/FAA/AR-01/37 (*see* 4.1.2).

4.4 Carbon Dioxide.

4.4.1 For occupied spaces on aircraft, carbon dioxide (CO_2) extinguishers shall not be used.

4.4.2 For cargo compartments of Combi aircraft and cargo aircraft, CO_2 extinguishers shall not be used.

4.5 Dry Chemical.

4.5.1* For occupied spaces on aircraft, dry chemical extinguishers shall not be used.

4.5.2 For cargo compartments of Combi aircraft and cargo aircraft, dry chemical extinguishers shall be not less than 4.5 kg (10 lb) capacity and shall have a minimum rating of 2-A:40-B:C.

4.6 Dry Powder.

4.6.1* For occupied spaces on aircraft, dry powder extinguishers for Class D fires shall not be used.

4.6.2 For accessible cargo compartments of Combi aircraft and cargo aircraft, dry powder extinguishers for Class D fires shall be permitted to be provided in addition to required extinguishers specified in 5.2.2.

4.7 Other Agents. Hand portable fire extinguishers carrying non-halogenated-type agents that were developed to replace halon shall be listed and labeled.

5.1.2 Where an extinguisher other than a water extinguisher is located within 1.5 m (5 ft) of, and on the same floor level as, a galley opening, an additional extinguisher shall not be required for the galley.

5.1.3 Where distances between extinguishers, as measured by normal aisle travel, exceed 18 m (60 ft), extinguishers in addition to those required by Table 5.1.1 shall be provided so that no travel distance to an extinguisher exceeds 9 m (30 ft).

5.1.4 Where aircraft passenger compartments, galleys, or lounge areas are on a separate level, such compartments or areas shall have extinguishers in accordance with Table 5.1.1.

5.1.5 Extinguishers in passenger compartments shall be readily accessible, mounted for quick removal, and installed on bulkheads wherever possible.

5.1.5.1 Where installation is necessary in overhead storage spaces, extinguishers shall be located so that carry-on luggage cannot interfere with extinguisher accessibility.

Chapter 5 Distribution of Extinguishers

5.1 Passenger Aircraft.

5.1.1 Aircraft hand portable fire extinguishers shall be placed in occupied spaces on aircraft as specified in Table 5.1.1.

Table 5.1.1 Distribution of Extinguishers in Occupied Spaces on Aircraft

Maximum Certificated Occupant Capacity	Number of Extinguishers	Type of Extinguisher	Location
1-4 (including pilot)	1	Halogenated agent (<i>see 4.3.2.1.2, 4.3.2.3</i>)	Within reach of seated pilot
5-30	1	Halogenated agent	Within reach of seated pilot
	1	Halogenated agent	Cabin
31-60	1	Halogenated agent	Flight deck
	2	One water and one halogenated agent	Cabin
	1	Halogenated agent	Each galley*
61-120	1	Halogenated agent	Flight deck
	3	One water and two halogenated agents	Cabin
	1	Halogenated agent	Each galley*
121-200	1	Halogenated agent	Flight deck
	4	Two water and two halogenated agents	Cabin
	1	Halogenated agent	Each galley*
201-275	1	Halogenated agent	Flight deck
	5	Two water and three halogenated agents	Cabin
	1	Halogenated agent	Each galley*
276-400	1	Halogenated agent	Flight deck
	8	Four water and four halogenated agents	Cabin
	1	Halogenated agent	Each galley*
> 400	1	Halogenated agent	Flight deck
	10	Five water and five halogenated agents	Cabin
	1	Halogenated agent	Each galley*
Combi aircraft wide-body	1	Halogenated agent	Flight deck
	5	Two water and three halogenated agents	Cabin
	1	Halogenated agent	Each galley*
	6	Four halogenated agents and two water	Cargo (passenger level)
Combi aircraft narrow-body	1	Halogenated agent	Flight deck
	4	Two water and two halogenated agents	Cabin
	1	Halogenated agent	Each galley*
	4	Two halogenated agents and two water	Cargo (passenger level)

*See 5.1.2.

5.1.5.2 Extinguisher locations shall be marked and shall be visible to occupants of the compartment.

5.1.6 Personal Breathing Equipment.

5.1.6.1 Personal breathing equipment (PBE) approved and maintained as specified by the authority having jurisdiction shall be provided.

5.1.6.2 The PBE shall be provided within 0.9 m (3 ft) laterally of all hand portable fire extinguishers.

5.2 Cargo Aircraft.

5.2.1 Occupied Spaces on Aircraft. The flight deck of cargo aircraft shall be provided with one halogenated agent extinguisher.

5.2.2 Cargo Compartment.

5.2.2.1 Where fixed extinguishing systems provide protection for the entire cargo compartment(s), or where the cargo compartment(s) is not accessible during flight, hand portable fire extinguishers shall not be required for the cargo compartment(s).

5.2.2.2* Where fixed extinguishing systems do not provide protection for the entire cargo compartment(s), a minimum of one hand portable fire extinguisher having a minimum capacity of 4.5 kg (10 lb) and a minimum rating of 2-A:40-B:C shall be provided and shall be equipped with a discharge hose or wand with a minimum length of 304 mm (12 in.).

5.2.2.2.1 The hand portable fire extinguisher specified in 5.2.2.2 shall be located and accessible inside the cargo compartment at the interior access entry.

5.2.2.2.2 Any additional hand portable fire extinguishers provided for cargo compartment use shall also be located in the cargo compartment.

5.2.2.3 Self-Contained Breathing Apparatus.

5.2.2.3.1 A self-contained breathing apparatus (SCBA), approved and maintained as specified by the authority having jurisdiction, with a minimum rated service life of 15 minutes and equipped with a full facepiece shall be provided.

5.2.2.3.2 The SCBA shall be accessible in a marked location outside the cargo compartment positioned adjacent to the access entry point.

5.3 Combi Aircraft.

5.3.1 Aircraft hand portable fire extinguishers shall be placed in the flight deck, passenger cabin, and cargo compartment on aircraft as specified in Table 5.1.1.

5.3.2 Where an extinguisher other than a water extinguisher is located within 1.5 m (5 ft) of, and on the same floor level as, a galley opening, an additional extinguisher shall not be required for the galley.

5.3.3 The minimum number of hand portable fire extinguishers necessary for the cargo compartment shall be as specified in Table 5.1.1.

5.3.4 Hand portable fire extinguishers shall be placed adjacent to the entrance door of the passenger deck (cargo compartment) and adjacent to the rear exit door of the aircraft.

5.3.5 Hand portable fire extinguishers shall be provided in the flight crew rest facilities.

Chapter 6 Inspection, Maintenance, and Hydrostatic Testing

6.1 Preflight Inspection.

6.1.1 One or more members of the flight crew shall make a preflight inspection of all extinguishers.

6.1.2 The inspection shall determine that all required extinguishers are provided, ready for use, in the assigned location, and secured.

6.1.3 Where provided, extinguisher pressure gauges shall indicate acceptable pressure, and seals and seal wires shall not be broken.

6.2 Maintenance.

6.2.1 Extinguishers shall be maintained in accordance with Chapter 6 of NFPA 10, and records shall be kept in accordance with those requirements.

6.2.2 Recharging procedures shall follow the requirements of Chapter 6 of NFPA 10.

6.2.3 Extinguishers that are out of service for maintenance or recharge shall be replaced with extinguishers having the same agent, rating, and operating procedure.

6.3 Hydrostatic Testing. Extinguisher shells and appurtenant devices such as nozzles, hoses, and pressure cartridges shall be hydrostatically tested in accordance with Chapter 7 of NFPA 10.

Chapter 7 Flight Crew Training

7.1 General.

7.1.1 Initially, before assignment, and at least annually thereafter, flight crew members shall receive theoretical and practical training in the basics of fire extinguishment.

7.1.1.1 Instruction on location and use of hand portable fire extinguishers on the aircraft for which flight crew members will be qualified shall be provided.

7.1.2 Training shall be conducted by instructors who are knowledgeable of the aircraft environment and experienced in the extinguishment of fire using hand portable fire extinguishers.

7.1.3 Training shall include the following:

- (1) Classroom instruction
- (2) Practical use of hand portable fire extinguishers
- (3) Extinguishment of a hot fire
- (4) Movement in a smoke-filled environment
- (5) Wearing of PBE, within a replica of an aircraft cabin environment

7.1.3.1 Halon shall not be discharged during training, as per 7.3.3.3.

7.1.3.2 Halocarbon extinguishers shall be permitted to be discharged during training, unless restricted by the authority having jurisdiction.

7.2* Classroom/Fire Scenario Instruction.

7.2.1 Classroom instruction concerning all types of extinguishers discussed in this standard shall be given to flight crews and shall include the following topics as a minimum:

- (1) Chemistry of fire and fire extinguishment
- (2) Severity potential of aircraft fires
- (3) Types of combustibles available in aircraft

- (4) Identification and choice of proper extinguisher
- (5) Consequences of misapplication of extinguishers
- (6) Relative effectiveness of extinguishers
- (7) Inspection requirements
- (8) Health and operational safety concerns

7.2.2 Practical Smoke Training. On aircraft types in which it is provided, training shall be given on the use of appropriate PBE when using an extinguisher in a simulated smoke-filled environment.

7.3 Manipulative Skills Training.

7.3.1 Training shall include each flight crew member demonstrating operation and use of hand portable extinguishers.

7.3.2 Training shall be representative of an interior aircraft fire, using the relevant type of hand portable fire extinguishers carried on the aircraft.

7.3.3* Each flight crew member shall demonstrate the knowledge and skill required to select the appropriate hand portable fire extinguisher for various fire scenarios and to properly apply the agent.

7.3.3.1 The overall training plan shall include representative aircraft fires of Class A, B, and C, as well as combined Class A and B fires.

7.3.3.2 Fire scenarios shall include galley, lavatory or closed compartment, flight deck, open cabins, and flammable liquid fires.

7.3.3.3 Extinguishers containing halon shall not be discharged during routine manipulative skills training.

7.3.3.3.1 Halon agent shall be conserved and shall be permitted to be used only to combat unwanted fires.

7.3.3.3.2 Suitable substitutes shall be permitted to be used for training with the approval of the authority having jurisdiction.

7.3.3.4 Any alternative agent approved by the authority having jurisdiction shall be listed and labeled.

7.4* Combi Aircraft.

7.4.1 The following items shall form the basis of the required course of instruction for flight crew involving Combi aircraft operations:

- (1) Explanation of fire risks with Combi operations
- (2) Chemistry of fire
- (3) Theory of extinguishing agents
- (4) Aircraft layout
- (5) Cargo loading requirements
- (6) Hazardous cargo consignments
- (7) Scale of Combi fire-fighting equipment (*see Table 5.1.1*)
- (8) Designated fire fighter duties including the following:
 - (a) Preflight audit
 - (b) Inflight inspection
 - (c) Fire control techniques
 - (d) Postfire information feedback
- (9) Practical demonstration and use of hand portable fire extinguishers
- (10) Practical exercises involving simulated fire situations

7.4.2 The facility used for training flight crews shall be representative of actual fire conditions and include the following:

- (1) An enclosed environment in which the trainee can experience the effects of fire and heat

- (2) A demonstration of the effectiveness of fire extinguishers when correctly applied to an actual fire
- (3) A facility in which to demonstrate an electrical fire
- (4) An exercise that includes dressing in the protective clothing and PBE provided onboard the aircraft and entering a simulated smoke-filled environment carrying a hand portable fire extinguisher as carried on the aircraft

7.5 Recurrent Training and Testing.

7.5.1* Recurrent training shall include discussions on recent onboard aircraft fire incidents.

7.5.2 Recurrent training shall be provided at intervals not exceeding 3 years.

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.2.1 In an aircraft fire, the integrity of the aircraft must be preserved and the flight crew must retain their physiological ability to fly the airplane (e.g., vision and consciousness). The overall threat to life must be held at the lowest possible level.

A.1.2.2 Additional information on the effectiveness and suitability of various aircraft hand portable fire extinguishers can be found in DOT/FAA/CT-82/42.

A.3.2.1 Approved. The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

A.3.2.2 Authority Having Jurisdiction (AHJ). The phrase "authority having jurisdiction," or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.3.2.4 Listed. The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

A.3.3.8.1 Class A Fires. European fire class designations are as follows:

- (1) Class A — Wood, paper, cloth, and so forth
- (2) Class B — Flammable liquids
- (3) Class C — Flammable gases
- (4) Class D — Metal fires
- (5) Class E — Electrical fires

The classification of fire extinguishers consists of one or more capital letters that indicate the classes of fire on which an extinguisher has been found to be effective. The letters (A and B only) are preceded by a rating number that indicates the relative extinguishing effectiveness.

It should be noted that European fire extinguisher ratings are not comparable with U.S. or Canadian ratings. In the United Kingdom, the applicable standards are British Standard 5306, Part 3, and British Standard 5423.

A.3.3.8.3 Class C Fires. When electrical equipment is de-energized, fire extinguishers for Class A or B fires can be used safely.

A.3.3.10 Flight Deck. Berths, galleys, and lavatory facilities can be associated with the flight crew compartment but are not included in the term *flight deck*.

A.3.3.11 Galley. Such areas typically include areas for plastic trays, plastic dinnerware utensils, and paper napkins.

A.3.3.12 Halogenated Agents. Halon 1211 and Halon 1301 are included in the Montreal Protocol on Substances that Deplete the Ozone Layer signed September 16, 1987. The 1992 amendments to the protocol called for a cessation of production of Halon 1211 and Halon 1301 worldwide.

A.3.3.12.2 Halon 1211. Due to its relatively high boiling point 4°C (25°F), Halon 1211 discharges as an 85 percent liquid stream, offering long agent throw range.

A.3.3.12.3 Halon 1301. Halon 1301 offers limited Class A capability when used in hand portable fire extinguishers.

A.3.3.14 Maximum Certificated Occupant Capacity. In the United States, the authority having jurisdiction is the Federal Aviation Administration.

A.3.3.15 Rated/Rating. The rating is required to be in accordance with ANSI/UL 711.

A.4.1.4 Aircraft hand portable fire extinguishers must perform in an environment substantially more varied and more critical than those approved for use in most land surface applications. Design considerations for extinguisher body, valves, fittings, and associated hardware, including mounting brackets, also should include pressure variations, positive and negative accelerations, vibration, corrosion, and ambient temperature variations.

A.4.1.5 In the United States, the authority having jurisdiction is the Federal Aviation Administration. The AHJ in Europe is the Joint Aviation Authority, and the AHJ in Canada is Transport Canada.

A.4.3.1 Exposure to decomposed halogenated agents could produce varied central nervous system effects, depending on exposure concentration and time. Halogenated agents also decompose into products of greater toxicity when subjected to flame or to hot surfaces at approximately 482°C (900°F). See NFPA 12A for detailed information.

The expected potential exposure of decomposition products resulting from the application of approved halocarbon agent extinguishers to flames or hot surfaces was also addressed and found to be within acceptable limits in DOT/FAA/AR-01/37.

A.4.3.2 Halon 1211 extinguishers have their greatest effectiveness on Class B and Class C fires. Extinguishers with 4 kg (9 lb) or greater capacity also are rated for Class A fires. Extinguishers with capacity of less than 4 kg (9 lb), although not rated for use on Class A fires, have been shown to be effective in extinguishing surface Class A fires.

A.4.3.2.1.1 Halon 1211 extinguishers of less than 4 kg (9 lb) capacity are not always furnished with a discharge hose. However, for access to underseat, overhead, and other difficult-to-reach locations, consideration should be given to using extinguishers with a discharge hose of a minimum length of 304 mm (12 in.). Also, an extinguisher with a discharge hose is more likely to be properly held in an upright position during use.

A.4.3.2.1.2 For occupied spaces on small aircraft where natural state halon concentrations will be approaching allowable limits, Halon 1301 is the halogenated agent of choice for the following reasons:

- (1) Halon 1211 decomposes when exposed to flame, producing some toxic products of decomposition that are not produced by Halon 1301 and is, therefore, also considered more toxic in the decomposed state.
- (2) The following health and safety advantages associated with similar-volume occupied spaces on larger aircraft (flight decks) do not usually exist for the smaller aircraft:
 - (a) Forced ventilation system
 - (b) Availability of oxygen masks
 - (c) Availability of a second individual capable of flying the aircraft

A.4.5.1 Dry chemical agent causes visibility problems in occupied spaces and potentially severe contamination of aircraft electrical components.

A.4.6.1 Dry powder agent causes visibility problems in occupied spaces and potentially severe contamination of aircraft electrical components.

A.5.2.2.2 The hose or wand provides effective reach of the contents of the extinguisher to any part of the cargo.

A.7.2 Discussion of health and safety aspects should include hazards and warnings concerning toxicity of combustion products, as well as the effects of short-, intermediate-, and long-term exposure to the undecomposed agents.

A.7.3.3 Live fire training on representative aircraft fires is highly recommended for all flight crew members during both initial and recurrent training sessions. Live fire training provides flight crews with psychological conditioning, fire-fighting techniques, and knowledge of extinguishing agent capabilities and limitations under actual fire situations. The live fires used should be the scenarios required in 7.3.3.2.

A.7.4 On completion of the course, flight deck crews and flight attendants should be confident about the procedures and practical use of equipment while working under conditions of smoke and heat. Numbers of personnel receiving training at any one time should be limited in order to ensure that each individual receives adequate practical experience and that his or her performance can be assessed by instructional staff.

A.7.5.1 These discussions are particularly important when crews are assigned to more than one aircraft type.

Annex B Informational References

B.1 Referenced Publications. The following documents or portions thereof are referenced within this standard for informational purposes only and are thus not part of the requirements of this document unless also listed in Chapter 2.

B.1.1 NFPA Publication. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 12A, *Standard on Halon 1301 Fire Extinguishing Systems*, 2004 edition.

B.1.2 Other Publications.

B.1.2.1 British Standards Institution Publications. British Standards Institute, 389 Chiswick High Road, London, W4 4AL, United Kingdom.

British Standard 5306, Part 3, *Code of Practice for Selection, Installation, and Maintenance of Portable Fire Extinguishers*.

British Standard 5423, *Specification for Portable Fire Extinguishers*.

B.1.2.2 FAA Publications. Federal Aviation Administration, William J. Hughes Technical Center, Airport and Aircraft Safety, Research and Development Division, Atlantic City International Airport, NJ 08405.

DOT/FAA/AR-01/37, "Development of a Minimum Performance Standard for Hand-Held Fire Extinguishers as a Replacement for Halon 1211 on Civilian Transport Category Aircraft," August, 2002.

DOT/FAA/CT-82/42, "Study of Hand-Held Fire Extinguishers Aboard Civil Aviation Aircraft," L. M. Krasner, Final Report, June, 1982. Available from FM Global Research, 1301 Atwood Avenue, P.O. Box 7500, Johnston, RI 02919.

B.1.2.3 UL Publication. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.

ANSI/UL 711, *Standard for Safety Rating and Testing of Fire Extinguishers*, 2002.

B.2 Informational References. The following documents or portions thereof are listed here as informational resources only. They are not a part of the requirements of this document.

B.2.1 FAA Publications.

Advisory Circular 20-42C, "Hand Fire Extinguishers for Use in Aircraft," 1984.

DOT/FAA/CT-82/42, "Study of Hand-Held Fire Extinguishers Aboard Civil Aviation Aircraft," 1982.

DOT/FAA/CT-83/30, "Extinguisher Agent Behavior in a Ventilated Small Aircraft," 1984.

DOT/FAA/CT-86/5, "Halon Extinguisher Agent Behavior in a Ventilated Small Aircraft," 1986.

DOT/FAA/CT-86/26, "Halon Extinguishment of Small Aircraft Instrument Panel Fires," 1986.

DOT/FAA/CT-89/31, "Smoke and Extinguisher Agent Dispersion in a Small Pressurized Fuselage," 1990.

B.2.2 U.S. Government Publications. Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

Military Specification for Halon 1211, MIL-B-38741.

Military Specification for Halon 1301, MIL-M-12218C.

B.2.3 Other Publications. "The Development of a Hidden Fire Test for Aircraft Hand Extinguisher Applications," CAA Paper 95013, Kidde International.

"Modeling Cardiac Sensitization of Humans Exposed to Halon 1301 or Halon 1211 Aboard Aircraft," *Aviation, Space, and Environmental Medicine*, Vol. 72, No. 10, October 2001.

"Test and Evaluation of Halon 1211 Hand-Portable Fire Extinguishers for Use in Habitable and Cargo Compartments of USAF Aircraft," J. Walker and R. N. Vickers, Final Report, November, 1981, Engineering Services Laboratory, Air Force Engineering and Services Center, Tyndall Air Force Base; Report Number ESL-TR-81-22.

B.3 References for Extracts. The following documents are listed here to provide reference information, including title and edition, for extracts given throughout the nonmandatory sections of this standard as indicated by a reference in brackets [] following a section or paragraph. These documents are not a part of the requirements of this document unless also listed in Chapter 2 for other reasons.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2002 edition.

NFPA 402, *Guide for Aircraft Rescue and Fire Fighting Operations*, 2002 edition.

NFPA 410, *Standard on Aircraft Maintenance*, 2004 edition.

Index

© 2004 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

- A-**
- Aircraft**see specific type, e.g., Passenger aircraft
- Aircraft hand portable fire extinguishers (definition)** 3.3.2
- Approved (definition)** 3.2.1, A.3.2.1
- Authority having jurisdiction (definition)** 3.2.2, A.3.2.2
- B-**
- Bar**see Galley
- Buffet**see Galley
- C-**
- Capacities of extinguishers** Chap. 4
- Carbon dioxide extinguishers** 4.1.2(1)(a), 4.1.2(2)(a), 4.4
- Cargo aircraft**
- Carbon dioxide extinguishers 4.4.2, 4.5.2
- Definition 3.3.1.1
- Distribution of extinguishers 5.2, A.5.2.2.2
- Dry powder extinguishers 4.6.2
- Halogenated agent extinguishers 4.3.2.2, 5.2.1
- Cargo/baggage compartments** 5.2.2, A.5.2.2.2
- Carbon dioxide extinguishers 4.4.2
- Definition 3.3.5
- Distribution of extinguishers 5.1.1
- Dry chemical extinguishers 4.5.2
- Dry powder extinguishers 4.6.2
- Halon 1211 extinguishers 4.3.2.2
- Water-based extinguishers 4.2.3
- Classroom instruction** 7.1.3(1), 7.2, A.7.2
- Cockpit**see Flight deck
- Combi aircraft**
- Carbon dioxide extinguishers 4.4.2
- Definition 3.3.1.2
- Distribution of extinguishers 5.1.1, 5.3
- Dry chemical extinguishers 4.5.2
- Dry powder extinguishers 4.6.2
- Flight crew instruction 7.4, A.7.4
- Halogenated agent extinguishers 4.3.2.2, 5.1.1
- D-**
- Definitions** Chap. 3
- Distribution of extinguishers** Chap. 5
- Dry chemical extinguishers** 4.1.2(1)(a), 4.1.2(2)(b), 4.5, A.4.5.1
- Dry powder extinguishers** 4.6, A.4.6.1
- E-**
- Extinguishers**see Aircraft hand portable fire extinguishers
- F-**
- Film-forming foam extinguishers** 4.1.2(1)(a), 4.1.2(2)(c)
- Fire classifications**
- Class A fires 7.3.3.1, A.4.3.2
- Definition 3.3.8.1, A.3.3.8.1
- Class B fires 4.2.2, 7.3.3.1, A.4.3.2
- Definition 3.3.8.2
- Class C fires 4.2.2, 7.3.3.1, A.4.3.2
- Definition 3.3.8.3, A.3.3.8.3
- Class D fires 1.1.3, 4.2.2, 4.6.1, 4.6.2
- Definition 3.3.8.4
- Training for 7.3.3.1
- Fire extinguishers**see Aircraft hand portable fire extinguishers
- Fire scenario instruction** 7.2, A.7.2
- Fire test and performance standards** 4.1.1, 4.1.2
- Flight crew**
- Definition 3.3.9
- Inspection of extinguishers 6.1.1
- Training Chap. 7
- Flight deck** 5.1.1, 5.2.1, 5.3.1
- Definition 3.3.10, A.3.3.10
- G-**
- Galley** 5.1.2, 5.1.4, 5.3.2, 7.3.3.2
- Definition 3.3.11, A.3.3.11
- Distribution of extinguishers 5.1.1
- H-**
- Halocarbon extinguishers** 4.1.2(1)(b), 4.1.2(2)(f), 4.3.1.2, 4.3.2
- Halogenated agents** 4.3, 5.2.1, A.4.3.1, A.4.3.2
- Definition 3.3.12, A.3.3.12
- Distribution of extinguishers 5.1.1
- Halocarbon 3.3.12.1
- Halon 1211 4.3.2, A.4.3.2
- Definition 3.3.12.2, A.3.3.12.2
- Halon 1301 4.3.2.1.2, A.4.3.2.1.2
- Definition 3.3.12.3, A.3.3.12.3
- Performance standards 4.1.2(1)(a), 4.1.2(2)(d)
- Training with 7.3.3.3
- Hand fire extinguishers**see Aircraft hand portable fire extinguishers
- Hydrostatic testing** 6.3
- I-**
- Inspection, preflight** 6.1
- L-**
- Labeled/labeling** 4.1.2, 4.1.3
- Definition 3.2.3
- Listed/listing** 4.1.2, 4.1.3
- Definition 3.2.4, A.3.2.4
- Listing and labeling organization** 4.1.3
- M-**
- Maintenance** 6.2
- Manipulative skills training** 7.3, A.7.3.3
- Marking** 4.1.3.1, 4.1.3.2
- Maximum certified occupant capacity (definition)** 3.3.14, A.3.3.14
- N-**
- Non-halogenated agents** 4.7
- O-**
- Occupied spaces on aircraft**
- Carbon dioxide extinguishers 4.4.1
- Dry chemical extinguishers 4.5.1, A.4.5.1
- Dry powder extinguishers 4.6.1, A.4.6.1
- Halogenated agent extinguishers 4.3.2.1, A.4.3.2.1.2
- Passenger aircraft, extinguisher distribution in 5.1.1 to 5.1.5

-P-

Passenger aircraft	
Definition	3.3.1.3
Distribution of extinguishers	5.1
Personal breathing equipment (PBE)	5.1.6, 7.1.3(5), 7.2.2, 7.4.2(4)
Preflight inspection	6.1
Purpose of standard	1.2, A.1.2.1, A.1.2.2

-R-

Rated/rating (definition)	3.3.15, A.3.3.15
Recurrent training and testing	7.5, A.7.5.1
References	Chap. 2, Annex B
Respiratory protection	
Personal breathing equipment (PBE)	<i>see</i> Personal breathing equipment (PBE)
Self-contained breathing apparatus (SCBA)	5.2.2.3

-S-

Scope of standard	1.1
--------------------------------	-----

Self-contained breathing apparatus (SCBA)	5.2.2.3
Shall (definition)	3.2.5
Should (definition)	3.2.6
Smoke training, practical	7.2.2
Standard (definition)	3.2.7

-T-

Temperature ranges for operation	4.1.4, A.4.1.4
Testing	
Fire test and performance standards	4.1.1, 4.1.2
Hydrostatic	6.3
Recurrent testing of flight crew	7.5, A.7.5.1
Training, flight crew	Chap. 7

-W-

Water-based extinguishers	4.1.5, 4.2, A.4.1.5
Distribution of extinguishers	5.1.1
Performance standards	4.1.2(1) (a), 4.1.2(2) (c)