Pneumatic
Conveying
Systems for
Handling
Combustible
Materials
1990 Edition



#### NOTICE

All questions or other communications relating to this document should be sent only to NFPA Headquarters, addressed to the attention of the Committee responsible for the document.

For information on the procedures for requesting Technical Committees to issue Formal Interpretations, proposing Tentative Interim Amendments, proposing amendments for Committee consideration, and appeals on matters relating to the content of the document, write to the Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

A statement, written or oral, that is not processed in accordance with Section 16 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Users of this document should consult applicable Federal, State and local laws and regulations. NFPA does not, by the publication of this document, intend to urge action which is not in compliance with applicable laws and this document may not be construed as doing so.

#### Policy Adopted by NFPA Board of Directors on December 3, 1982

The Board of Directors reaffirms that the National Fire Protection Association recognizes that the toxicity of the products of combustion is an important factor in the loss of life from fire. NFPA has dealt with that subject in its technical committee documents for many years.

There is a concern that the growing use of synthetic materials may produce more or additional toxic products of combustion in a fire environment. The Board has, therefore, asked all NFPA technical committees to review the documents for which they are responsible to be sure that the documents respond to this current concern. To assist the committees in meeting this request, the Board has appointed an advisory committee to provide specific guidance to the technical committees on questions relating to assessing the hazards of the products of combustion.

**Licensing Provision** — This document is copyrighted by the National Fire Protection Association (NFPA).

- 1. Adoption by Reference Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders or similar instruments. Any deletions, additions and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.
- 2. Adoption by Transcription A. Public authorities with lawmaking or rule-making powers only, upon written notice to the NFPA (Attention: Secretary, Standards Council), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and, (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's lawmaking or rulemaking process. B. Once this NFPA Code or Standard has been adopted into law, all printings of this document by public authorities with lawmaking or rulemaking powers or any other persons desiring to reproduce this document or its contents as adopted by the jurisdiction in whole or in part, in any form, upon written request to NFPA (Attention: Secretary, Standards Council), will be granted a nonexclusive license to print, republish, and vend this document in whole or in part, with changes and additions, if any, noted separately provided that due notice of NFPA's copyright is contained in each copy. Such license shall be granted only upon agreement to pay NFPA a royalty. This royalty is required to provide funds for the research and development necessary to continue the work of NFPA and its volunteers in continually updating and revising NFPA standards. Under certain circumstances, public authorities with lawmaking or rulemaking powers may apply for and may receive a special royalty when the public interest will be served thereby.
- 3. Scope of License Grant The terms and conditions set forth above do not extend to the index to this document.

(For further explanation, see the Policy Concerning the Adoption, Printing and Publication of NFPA Documents which is available upon request from the NFPA.)

#### Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accepts any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

# CHARLES S. MORGAN LIBRARY NATIONAL FIRE PROTECTION ASSOCIATION 1 BATTERYMARCH PARK QUINCY, MA 02269-9101

Copyright © 1990 NFPA, All Rights Reserved

#### **NFPA 650**

#### Standard for

#### Pneumatic Conveying Systems for Handling Combustible Materials

#### 1990 Edition

This edition of NFPA 650, Standard for Pneumatic Conveying Systems for Handling Combustible Materials, was prepared by the Technical Committee on Fundamentals of Dust Explosion Prevention and Control, released by the Correlating Committee on Dust Explosion Hazards, and acted on by the National Fire Protection Association, Inc. at its Fall Meeting held November 13-15, 1989 in Seattle, WA. It was issued by the Standards Council on January 12, 1990, with an effective date of February 5, 1990, and supersedes all previous editions.

The 1990 edition of this document has been approved by the American National Standards Institute.

Changes other than editorial are indicated by a vertical rule in the margin of the pages on which they appear. These lines are included as an aid to the user in identifying changes from the previous edition.

#### Origin and Development of NFPA 650

NFPA 650 had its origin as NFPA 66, Standard for Pneumatic Conveying Systems for Handling Feed, Flour, Grain and Other Agricultural Dusts. NFPA 66 was adopted as a tentative standard in 1963, and as a standard in 1964. Revised standards were adopted in 1970 and 1973.

NFPA 650-1984, Standard for Pneumatic Conveying Systems for Handling Combustible Materials, in addition to being different in title from NFPA 66, differs in scope and represents a complete rewrite of NFPA 66. The rewrite makes the standard applicable to the pneumatic conveying of combustible materials, both agricultural and non-agricultural.

The 1990 edition of NFPA 650 is a reconfirmation of the 1984 edition.

# Technical Committee on Dust Explosion Hazards SAMYRE IA8 [ Gorrelating Committee

**Thomas E. Frank,** Factory Mutual Engr. Assn. **Robert W. Nelson,** Industrial Risk Insurers

Anthony G. Martino, Cargill, Inc.

## Technical Committee on Fundamentals of Dust Explosion Prevention and Control

Robert W. Nelson, Chairman Industrial Risk Insurers

A. Richard Albrecht, Dow Chemical Co.
C. James Dahn, Safety Consulting Engineers, Inc.
John T. Higgins, Dow Corning Corp.
David C. Kirby, Union Carbide Corp.
Larry J. Moore, Factory Mutual Research Corp.
Michael E. Mowrer, Professional Loss Control Inc.
Parker Peterson, Fenwal Inc.

R. F. Schwab, Allied-Signal Inc.
Rep. Society of Plastics Industries
Ian Swift, Hazards Testing and Consulting, Inc.
William T. Trinker, The Mill Mutuals
Harold H. Weber, The Sulphur Institute
(Vote Limited to NFPA 655)

#### Alternates

Joseph P. Gillis, Fenwal Inc.
(Alternate to P. Peterson)

Edward D. Leedy, Industrial Risk Insurers
(Alternate to R. W. Nelson)

James E. Maness, Bunge Corp.
(Alternate to Grain Elevator and Processing Society Rep.)

F. Tamanini, Factory Mutual Research Corp. (Alternate to L. J. Moore)

Harry Verakis, Mine Safety & Health Admin. (Alternate to MS&HA Rep.)

Martha H. Curtis, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the text of this edition. Since that time, changes in the membership may have occurred.

NOTE: Membership on a Committee shall not in and of itself constitute an endorsement of the Association or any document developed by the Committee on which the member serves.

#### **Contents**

Chapter 1 General	
1-1 Scope	
1-2 Purpose	<b>650</b> - 5
1-3 Retroactivity	<b>650</b> - 5
1-4 Definitions	
1-5 General Design	
Chapter 2 Tubing, Headers, Manifolds, Ducts	<b>650</b> – 6
2-1 Design	<b>650</b> – 6
# · 2000	
Chapter 3 Valves	650- 7
3-1 Pressure Relief Valves	
3-2 Multiple Direction Valves	
3-3 Air Flow Control Valves	650_ 7
5-5 All Flow Collifor Valves	030- 7
Chamban A. Ain Matanial Samanatana	650 7
Chapter 4 Air-Material Separators	
4-1 General	050- 7
4-2 Construction	
4-3 Location	
4-4 Protection	650- 8
Chapter 5 Feeding Methods	650- 8
5-1 Hoppers	650- 8
5-2 Mechanical Devices	
5-3 Drives	<b>650</b> – 8
Chapter 6 Fans and Blowers	
6-1 Design and Installation	
6-2 Maintenance	
6-3 Operation	<b>650</b> – 8
Chapter 7 Portable Conveying Units, Including Bulk Trucks	<b>650</b> – 8
7-1 Engine and Motor Driven Equipment	<b>650</b> – 8
7-2 Bonding and Grounding	650- 9
7-3 Dust Control	<b>650</b> - 9
Chapter 8 Training and Inspection	650- 9
8-1 Employee Training	<b>650</b> – 9
8-2 Periodic Inspection	
1	
Chapter 9 Referenced Publications	650- 9
Chapter b References 2 abricanons	
Appendix A	650 10
Appendix A	050-10
A	CEO 1
Appendix B Referenced Publications	UDU-1.
Access to the contract of the	CFO 1
Appendix C Schematics of Typical Pneumatic Conveying Installations	050-1
• •	0F0 -
Index	650-14

#### **NFPA 650**

#### Standard for

#### **Pneumatic Conveying Systems for Handling**

#### Combustible Materials

#### 1990 Edition

NOTE: An asterisk (\*) following the number or letter designating a paragraph indicates explanatory material on that paragraph in Appendix A.

Information on referenced publications can be found in Chapter 9 and Appendix B.

#### Chapter 1 General

#### 1-1 Scope.

- 1-1.1 This standard shall apply to the pneumatic conveying of combustible materials.
- 1-1.2 This standard shall not apply to the pneumatic conveying of materials covered by:
- NFPA 43A, Code for the Storage of Liquid and Solid Oxidizing Materials, (Class 3 and 4 oxidizing materials only)
- NFPA 61A, Standard for the Prevention of Fire and Dust Explosions in Facilities Manufacturing and Handling Starch
- NFPA 61B, Standard for the Prevention of Fires and Explosions in Grain Elevators and Facilities Handling Bulk Raw Agricultural Commodities
- NFPA 61C, Standard for the Prevention of Fire and Dust Explosions in Feed Mills
- NFPA 61D, Standard for the Prevention of Fire and Dust Explosions in the Milling of Agricultural Commodities for Human Consumption
- NFPA 65, Standard for the Processing and Finishing of Aluminum
- NFPA 85F, Standard for the Installation and Operation of Pulverized Fuel Systems
- NFPA 120, Standard for Coal Preparation Plants
- NFPA 480, Standard for the Storage, Handling, and Processing of Magnesium
- NFPA 482, Standard for the Production, Processing, Handling, and Storage of Zirconium
- NFPA 495, Code for the Manufacture, Transportation, Storage and Use of Explosive Materials
- NFPA 651, Standard for the Manufacture of Aluminum and Magnesium Powder
- NFPA 664, Standard for the Prevention of Fires and Explosions in Wood Processing and Woodworking Facilities.

#### 1-2 Purpose.

- 1-2.1 The purpose of this standard is to prescribe reasonable requirements for safety to life and property from fire and explosion and to minimize the resulting damage should a fire or explosion occur.
- 1-2.2 This standard is not intended to prevent the use of systems, methods, or devices that provide equivalent protection from fire and explosion, providing that suitable data is available to demonstrate equivalency.
- 1-3 Retroactivity. This standard applies to facilities on which construction is begun subsequent to the date of publication of this standard. When major replacement or renovation of existing facilities is planned, provisions of this standard shall apply.
- 1-4 **Definitions.** For the purposes of this standard, the following terms shall have the meanings given below.

**Approved.** Acceptable to the "authority having jurisdiction."

NOTE: The National Fire Protection Association does not approve, inspect or certify any installations, procedures, equipment, or materials nor does it approve or evaluate testing laboratories. In determining the acceptability of installations or procedures, equipment or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization concerned with product evaluations which is in a position to determine compliance with appropriate standards for the current production of listed items.

**Authority Having Jurisdiction.** The "authority having jurisdiction" is the organization, office or individual responsible for "approving" equipment, an installation or a procedure.

NOTE: The phrase "authority having jurisdiction" is used in NFPA documents in a broad manner since jurisdictions and "approval" agencies vary as do their responsibilities. Where public safety is primary, the "authority having jurisdiction" may be a federal, state, local or other regional department or individual such as a fire chief, fire marshal, chief of a fire prevention bureau, labor department, health department, building official, electrical inspector, or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the "authority having jurisdiction." In many circumstances the property owner or his designated agent assumes the role of the "authority having jurisdiction"; at government installations, the commanding officer or departmental official may be the "authority having jurisdiction."

Combustible Dust.\* Any finely divided solid material 420 microns or smaller in diameter (material passing a U. S. No. 40 Standard Sieve) that presents a fire or explosion hazard.

**Detachment.** In the open air or in a separate building.

**Duct.** That part of a system that conveys air to or from primary and/or secondary air-material separators.

**Header.** That part of a system located between the air discharge of a primary or secondary air-material separator and the air intake of the prime air mover (blower or fan), which conveys the air discharge from only a single separator at any one time.

**Hybrid Mixture.** A combination of combustible dust and flammable gas or vapor that can be ignited.

Labeled. Equipment or materials to which has been attached a label, symbol or other identifying mark of an organization acceptable to the "authority having jurisdiction" and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

Listed. Equipment or materials included in a list published by an organization acceptable to the "authority having jurisdiction" and concerned with product evaluation, that maintains periodic inspection of production of listed equipment or materials and whose listing states either that the equipment or material meets appropriate standards or has been tested and found suitable for use in a specified manner.

NOTE: The means for identifying listed equipment may vary for each organization concerned with product evaluation, some of which do not recognize equipment as listed unless it is also labeled. The "authority having jurisdiction" should utilize the system employed by the listing organization to identify a listed product.

**Manifold.** A header that simultaneously serves more than one air-material separator on a suction-type pneumatic system and that normally operates at a negative pressure.

**Multiple Strand.** The arrangement of several suction-type pneumatic systems served by a single manifold.

**Pneumatic Conveying System.** A system consisting of an enclosed tubing system in which a material is transported by a stream of air having a sufficiently high velocity to keep the conveyed material in motion. Noncombustible, nonreactive gases may be used in place of, or mixed with, air.

Such systems are of two principal types or a combination of the two types.

- (a) Positive Pressure-Type. Pressure-type systems transport material by utilizing air at greater than atmospheric pressure. Such systems basically consist of a blower drawing air through a filter; an air-lock feeder for introducing materials into the system; tubing or ducts; and a suitable air-material separator.
- (b) Negative Pressure-Type. Negative pressure-type systems transport material by utilizing air at less than atmospheric pressure. These systems basically consist of a material and air intake; tubing or ducts; a suitable air-material separator; and a fan or blower.

**Primary Air-Material Separator.** A collector that removes the bulk of the product or material from the conveying air stream.

**Secondary Air-Material Separator.** A device for removing the residual dust or product remaining in the air stream after the primary air-material separator.

**Tubing.** The part of a system located between the point of infeed and the primary air-material separator through which heavy concentrations of product are conveyed.

#### 1-5 General Design.

- 1-5.1 All system components shall be conductive. Bonding and grounding shall be provided. (See NFPA 77, Recommended Practice on Static Electricity.)
- 1-5.2 All electrical equipment in and around the pneumatic system shall be designed and installed in accordance with NFPA 70, *National Electrical Code*\*.
- 1-5.3 All systems shall be designed to be air-tight and dusttight except at openings designed for intake and discharge of air and material.
- 1-5.4 Where more than one material is to be handled by a system, compatibility tests shall be run; and where incompatability is found, provisions shall be made for cleaning of the system prior to transport of a new material.
- 1-5.5 Equipment and bins shall be provided with explosion prevention or explosion protection in accordance with either 1-5.5.1, 1-5.5.2, or 1-5.5.3.
- 1-5.5.1 Explosion venting may be provided. (See NFPA 68, Guide for Venting of Deflagrations.)
- 1-5.5.2 The container and system may be designed to contain the explosion pressure.
- 1-5.5.3 Explosion prevention systems in accordance with NFPA 69, Standard on Explosion Prevention Systems, may be installed.

#### 1-5.6 Hybrid Mixtures.

- 1-5.6.1\* Where inert gas is used, oxygen monitors shall be required and shall sound an alarm at a preset level.
- 1-5.6.2 When hybrid mixtures are transported, recycling of the gas stream to any work space shall not be permitted.

#### Chapter 2 Tubing, Headers, Manifolds, Ducts

#### 2-1\* Design.

**2-1.1** Where a system or any part of a system operates as a positive pressure-type system and the blower discharge pressure is 15 psig (103 kPa) or greater, the system shall be designed in accordance with ASME Boiler and Pressure Vessel Code, Section VIII or ANSI/ASME B31.3, Chemical Plant and Petroleum Refinery Piping.

#### 2-1.2 Elbows.

2-1.2.1 All elbows shall be of air- and dust-tight construction.

- 2-1.2.2 Joints shall be butted squarely and air- and dust-tight.
- **2-1.3** All parts of a system located within buildings shall be permanently assembled with no temporary connections that may be left open and permit the escape of material from the system.
- 2-1.4 Connections between individual lengths, elbows, or other pneumatic equipment shall be air- and dust-tight.

#### 2-1.5 Support.

- **2-1.5.1** All tubing, headers, manifold, and ducts shall be supported so as to avoid excessive stress or strain.
- 2-1.5.2 Supports shall be designed to include the weight of the system and the transported material.
- **2-1.5.3** Vertical runs through floors shall be securely fastened at each floor level.
- **2-1.5.4** Tubing or ducts that pass through fire barrier or fire walls shall be rigidly supported on both sides, and the opening around the duct shall be sealed to the full thickness of the wall with a material of a fire resistance rating equivalent to that of the wall.

#### 2-1.6 Sight Glasses.

- 2-1.6.1 Sight glasses, if installed, shall be of a material that is not readily damaged. Tubing shall be supported above and below each sight glass so that the sight glass does not carry any of the system weight and is not subject to stress or strain.
- 2-1.6.2 The electrical bonding of the system shall be continuous around all sight glasses. The strength of the sight glass and its mounting mechanism and its inside diameter shall be equal to the adjoining tube system.
- **2-1.6.3** Connections between the sight glass and tubing shall be butted squarely and sealed so as to be air-tight and dust-tight.
- 2-1.7 All tubing, headers, manifolds, and ducts shall be provided with access panels for examining and cleaning of system in accordance with NFPA 91, Standard for the Installation of Blower and Exhaust Systems for Dust, Stock, and Vapor Removal or Conveying.

#### Chapter 3 Valves

- **3-1 Pressure Relief Valves.** One or more relief valves for both positive pressure and negative pressure pneumatic systems shall be located, sized, and set to relieve at pressures designed to protect the system components. Valves to protect the blower package shall be installed on the clean air side of the system.
- **3-2 Multiple Direction Valves.** Multiple direction valves shall be of air- and dust-tight construction and shall effect a positive diversion of the conveyed product. Diversion of the

product in one direction shall mechanically and automatically seal all other directions from air and dust leakage.

#### 3-3 Air Flow Control Valves.

- **3-3.1** Air flow control valves installed in multiple strand suction-type pneumatic systems shall be of air- and dust-tight construction and shall inject sufficient static resistance to allow air flow adjustment for system balancing purposes. Valves shall be sized to pass the total air flow of the system with dampers in the wide open position. Valves shall be so constructed as to totally shut off air flow in the system.
- **3-3.2** Valves shall have visible scales to indicate the position of control dampers.
- **3-3.3** Manually adjusted valves shall have a locking device to prevent movement of dampers once set.

#### Chapter 4 Air-Material Separators

#### 4-1 General.

- **4-1.1** Air-material separators that are located outside and on top of structures shall be provided with lightning protection in accordance with NFPA 78, Lightning Protection Code.
- **4-1.2** Material discharge outlets from air-material separators shall be provided with a positive choke device.
- **4-1.3** Exhaust air from air-material separators shall be discharged outside of building.

Exception No. 1: Where provision is made to recycle transport air directly back into the pneumatic conveying system.

Exception No. 2: Where all ducts returning air to the building are equipped and protected as indicated in 4-1.4.

#### 4-1.4 Return Air Ducts.

- **4-1.4.1** Ducts shall be equipped with a filter other than the primary or secondary air-material separator.
- **4-1.4.2** Filters shall have a 99.5 percent efficiency for particle sizes of 1.0 micron diameter and greater.

#### 4-2 Construction.

**4-2.1** Air-material separators shall be constructed of noncombustible materials.

Exception: Filter media may be of combustible material.

- **4-2.2** Air-material separators shall be constructed so as to eliminate internal ledges or other points of dust accumulation. Hopper bottoms shall be sloped, and the discharge conveying system shall be designed to handle maximum flow.
- **4-2.3** Cleanout doors or panels shall be provided for access to the interior.
- **4-2.4** Air-material separators shall be provided with explosion relief. (See NFPA 68, Guide for Venting of Deflagrations.)

Exception: When protection is provided in accordance with 4-4.1, 4-4.2, or 4-4.3.

**4-3 Location.** Air-material separators shall be located outside of buildings.

Exception No. 1: Separators may be located inside of buildings if located adjacent to an exterior wall and vented to the outside through straight and short ducts, not exceeding 10 ft (3.05 m) in length, designed according to information contained in NFPA 68, Guide for Venting of Deflagrations, and designed so that explosion pressures will not rupture the ductwork or the separator.

Exception No. 2: Separators protected in accordance with Section 4-4.

#### 4-4\* Protection.

- **4-4.1** Air-material separators may be equipped with an explosion suppression system. The explosion suppression system shall be designed and installed in accordance with NFPA 69, Standard on Explosion Prevention Systems.
- **4-4.2** Air-material separator systems may be designed to operate using an inert or oxygen deficient gas as a transfer medium provided that such systems are designed and installed in accordance with NFPA 69, Standard on Explosion Prevention Systems.
- **4-4.3** Air-material separators may be designed to withstand maximum peak explosion pressure.

#### Chapter 5 Feeding Methods

- **5-1 Hoppers.** When material is introduced into the pneumatic system through a hopper and feeding device, such hopper shall be dust-tight and designed for pressure equalization.
- **5-2\* Mechanical Devices.** Mechanical feeding devices shall be equipped with a shear pin or overload detection device and alarm.
- **5-3 Drives.** All drives used in connection with feeders, air locks, and other devices shall be direct connected.

Exception: Belt or other indirect-type drives designed to have a sufficient service factor to stall the driving forces without slipping, and providing for the removal of static electric charges.

#### Chapter 6 Fans and Blowers

#### 6-1 Design and Installation.

- **6-1.1** Fans and blowers shall be designed and installed in accordance with NFPA 91, Standard for the Installation of Blower and Exhaust Systems for Dust, Stock, and Vapor Removal or Conveying.
- **6-1.2** Bearings or bearing housings shall be designed to prevent overheating, oil leakage, and dust infiltration.

#### 6-2 Maintenance.

- **6-2.1** Bearings shall be lubricated and checked for excessive wear on a periodic basis.
- **6-2.2** When the product has a tendency to stick to the rotor or housing, the rotor shall be cleaned periodically to maintain good balance, and the housing shall be cleaned periodically to minimize the possibility of ignition, especially when exposed to heated air.
- **6-2.3** The interior surfaces of fan housings shall be maintained free from rust. Aluminum paint shall not be used on interior steel surfaces that may be struck by foreign material because of potential heat of impact.

#### 6-3 Operation.

- **6-3.1** Fans and blowers shall run at full speed before material is transported and after the material has ceased to be transported to clear the system of material.
- **6-3.2** Fans and blowers shall be checked periodically for excessive heat and vibration.
- **6-3.3** An interlock shall be provided to stop the material feed upon failure of the conveying system.

#### Chapter 7 Portable Conveying Units, Including Bulk Trucks

#### 7-1 Engine and Motor Driven Equipment.

- 7-1.1 Engine and motor driven equipment used in confined hazardous areas shall be equipped with safety devices designed to reduce the potential fire hazard and electrical shock hazard.
- 7-1.2\* Requirements for engine and motor driven equipment shall meet or exceed the requirements of the Firesafety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Maintenance and Operation, NFPA 505, for the following designations:
  - (a) Diesel powered units Type DS.
  - (b) Electrical powered units Type EE.
  - (c) Gasoline powered units Type GS.
  - (d) Liquefied petroleum gas powered units Type LPS.
  - (e) Dual powered units Type GS/LPS.
- **7-1.3** Spark arrestors shall be used on the exhaust stacks of all diesel powered units.
- 7-1.4 Refueling shall be conducted outdoors.
- **7-1.5\*** Surface dust shall be removed from engine and motor driven equipment at regular intervals during operation.

- **7-1.5.1** Cleaning with compressed air shall not be conducted in Class II hazardous locations.
- **7-1.5.2** Spark arrestors shall be cleaned or replaced according to the manufacturer's recommendations.
- 7-1.6 Maintenance procedures shall comply with the manufacturer's instructions, especially with regard to replacement of insulation, covers, electrical enclosures, and parts of the electrical system designed to reduce chafing of insulation or termination failure.

#### 7-2 Bonding and Grounding.

- **7-2.1** All equipment, such as truck, tank or hopper, conveyor tube, motor, or compressors, on a unit shall be electrically bonded and grounded.
- **7-2.2** Flexible tubing shall be electrically conductive. Connections from the transport vehicle to the receiving system shall be made on the outside of any building.
- **7-2.3** The operator shall ground the truck and bond the receiving tube to the truck and receiving equipment before starting the compressor. The compressor shall be at operating speed before transporting material.
- **7-2.4** Portable equipment electrical bonds shall be checked visually each time the equipment is used.

#### 7-3 Dust Control.

**7-3.1** The receiving bin or hopper shall have filtered open vents.

Exception: Filters may be omitted if the bin vent is piped back to the truck.

#### Chapter 8 Training and Inspection

#### 8-1 Employee Training.

- 8-1.1 There shall be policies and requirements that provide for initial and continuing training for all employees. These shall include the development of operating procedures that are reviewed by the management at least once per year and after every process change.
- 8-1.2 All employees shall be carefully and thoroughly instructed at scheduled intervals regarding the hazards of their working environment. Their reactions in cases of equipment or process failures may reduce the incidence of fires and prevent explosions.

#### 8-2 Periodic Inspection.

**8-2.1** A thorough systematic inspection for safe operation of items listed in 8-2.2 shall be made at regular intervals and shall be submitted to plant management for review.

- **8-2.2** The inspection shall include, but not be limited to, the following:
- (a) fire and explosion protection and prevention equipment;
  - (b) dust control equipment;
  - (c) housekeeping;
- (d)\* electrical and mechanical equipment, relief valves, and interlocks;
  - (e) procedures.
- **8-2.3** Competent persons shall conduct such inspections and the record of their findings and recommendations shall be recorded in the principal plant office.

#### **Chapter 9 Referenced Publications**

(See Appendix B for other referenced publications that are advisory and thus do not constitute part of the requirements of this document.)

- **9-1** The following documents or portions thereof are referenced within this standard and shall be considered part of the requirements of this document. The edition indicated for each reference is the current edition as of the date of the NFPA issuance of this document.
- **9-1.1 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 43A-1980, Code for the Storage of Liquid and Solid Oxidizing Materials (1-1.2)

NFPA 61A-1989, Standard for the Prevention of Fire and Dust Explosions in Facilities Manufacturing and Handling Starch (1-1.2)

NFPA 61B-1989, Standard for the Prevention of Fires and Explosions in Grain Elevators and Facilities Handling Bulk Raw Agricultural Commodities (1-1.2)

NFPA 61C-1989, Standard for the Prevention of Fire and Dust Explosions in Feed Mills (1-1.2)

NFPA 61D-1989, Standard for the Prevention of Fire and Dust Explosions in the Milling of Agricultural Commodities for Human Consumption (1-1.2)

NFPA 65-1987, Standard for the Processing and Finishing of Aluminum (1-1.2)

NFPA 69-1986, Standard on Explosion Prevention Systems (1-5.5.3, 4-4.1, 4-4.2)

NFPA 70-1987, National Electrical Code (1-5.2)

NFPA 78-1986, Lightning Protection Code (4-1.1)

NFPA 85F-1988, Standard for the Installation and Operation of Pulverized Fuel Systems (1-1.2)

NFPA 91-1990, Standard for the Installation of Blower and Exhaust Systems for Dust, Stock and Vapor Removal or Conveying (2-1.7, 6-1.1)

NFPA 120-1988, Standard for Coal Preparation Plants (1-1.2)

NFPA 480-1987, Standard for the Storage, Handling, and Processing of Magnesium (1-1.2)

NFPA 482-1987, Standard for the Production, Processing, Handling, and Storage of Zirconium (1-1.2)

NFPA 495-1985, Code for the Manufacture, Transportation, Storage and Use of Explosive Materials (1-1.2)

NFPA 505-1987, Firesafety Standard for Powered Industrial Trucks (7-1.2)

NFPA 651-1987, Standard for the Manufacture of Aluminum and Magnesium Powder (1-1.2)

NFPA 664-1987, Standard for the Prevention of Fires and Explosions in Wood Processing and Woodworking Facilities (1-1.2).

#### 9-1.2 Other Publications.

**9-1.2.1 ANSI Publication.** American National Standards Institute, 1430 Broadway, New York, NY, 10018.

ANSI/ASME B31.3-1976, Chemical Plant and Petroleum Refinery Piping (2-1.1)

9-1.2.2 ASME Publication. American Society of Mechanical Engineers, 345 East 47th Street, New York, NY, 10017.

ASME Boiler and Pressure Vessel Code, Section VIII (2-1.1)

#### Appendix A

This Appendix is not a part of the requirements of this NFPA document, but is included for information purposes only.

**A-1-4 Combustible Dust.** Any time a combustible dust is processed or handled, a potential for explosion exists. The degree of explosion hazard will vary depending on the type of combustible dust and processing methods used.

A dust explosion has four requirements:

- (a) A combustible dust,
- (b) A dust dispersion in air or oxygen at or exceeding the minimum explosion concentration, and
- (c) An ignition source such as a static, RF, or electric spark or arc; a glowing ember dust layer, hot surface, or weld slag; a friction heated bearing, pulley, rotor, fan; a flame or other source.
- (d) Confinement. Evaluation of the hazard of a combustible dust should be determined by the means of actual test data. All combustible dusts that may produce a dust explosion should be tested so as to determine the following data:
  - (1) Particle size distribution.
  - (2) Moisture content as received and dried.
  - (3) Minimum dust concentration to ignite.
  - (4) Minimum energy required for ignition (joules).
- (5) Maximum rate of pressure rise at optimum concentration.
  - (6) Layer ignition temperature.

- (7) Maximum explosion pressure, at optimum concentration.
  - (8) Electrical resistivity measurement.
  - (9) Dust cloud ignition temperature.

#### Optional Testing.

- (10) Maximum permissible oxygen content to prevent ignition.
- A-1-5.6.1 For oxygen concentration levels see NFPA 69, Standard on Explosion Prevention Systems.
- **A-2-1** Ducts should be equipped, where applicable, with an automatic spark detection and extinguishing system.
- A-4-4 Air-material separators containing combustible component parts should be equipped with an automatic sprinkling device in accordance with NFPA 13, Standard for Installation of Sprinkler Systems, or other special extinguishing system in accordance with NFPA 12, Standard on Carbon Dioxide Extinguishing Systems; NFPA 12A, Standard on Halon 1301 Fire Extinguishing Systems; or NFPA 12B, Standard on Halon 1211 Fire Extinguishing Systems.
- **A-5.2** Magnetic or other protective separating equipment should be provided to prevent entrance of ferrous materials into the pneumatic system. Removal of nonferrous material should be by screen or gravity separator or other device.
- **A-7-1.2** Refer to the following publications for further information:
- UL 558, Standard for Internal Combustion Engine Powered Industrial Trucks.
  - UL 583, Standard for Electric Battery Powered Industrial Trucks.
- (FM) Approval Standard for Gasoline or Diesel Engine Powered Industrial Trucks, Types G, GS, D, or DS.
- (FM) Approval Standard for Electrical Battery Powered Industrial Trucks, Types E and EE.
- (FM) Approval Standard for LP-Gas Engine Powered Industrial Trucks, Types LP and LPS.
- ANSI/ASME B56.1, Safety Standard for Powered Industrial Trucks.
- **A-7-1.5** Cleaning should be done at 1-hour intervals during periods of steady operation and at the end of each work day.
- **A-8-2.2(d)** Safety interlocks should be calibrated and tested at scheduled intervals in the manner in which they are intended to operate with written test records maintained and reviewed by management.

#### Appendix B Referenced Publications

**B-1** The following documents or portions thereof are referenced within this standard for informational purposes only and thus are not considered part of the requirements of this Standard. The edition indicated for each reference is the current edition as of the date of the NFPA issuance of this document.

**B-1.1 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 12-1989, Standard on Carbon Dioxide Extinguishing Systems (A-4-4)

NFPA 12A-1989, Standard on Halon 1301 Fire Extinguishing Systems (A-4-4)

NFPA 12B-1985, Standard on Halon 1211 Fire Extinguishing Systems (A-4-4)

NFPA 13-1989, Standard for the Installation of Sprinkler Systems (A-4-4)

NFPA 68-1988, Guide for Venting of Deflagrations (1-5.5.1, 4-2.4, 4-3 Exception No. 1)

NFPA 69-1986, Standard on Explosion Prevention Systems (A-1-5.6.2)

NFPA 77-1988, Recommended Practice on Static Electricity (1-5.1)

#### **B-1.2** Other Publications.

**B-1.2.1 ANSI Publication.** American National Standards Institute, 1430 Broadway, New York, NY, 10018.

ANSI/ASME B56.1, Safety Standard for Powered Industrial Trucks (A-7-1.2)

**B-1.2.2 FM Publications.** Factory Mutual Research Corportation, 1151 Boston-Providence Turnpike, Norwood, MA 02062

Approval Standard for Electrical Battery Powered Industrial Trucks, Types E and EE (A-7-1.2)

Approval Standard for Gasoline or Diesel Engine Powered Industrial Trucks, Types G, GS, D or DS (A-7-1.2)

Approval Standard for LP-Gas Engine Powered Industrial Trucks, Types LP and LPS (A-7-1.2)

**B-1.2.3 UL Publications.** Underwriters Laboratories Inc., 333 Pfingsten Rd., Northbrook, IL 60062.

UL 558, Standard for Internal Combustion Engine Powered Industrial Trucks (A-7-1.2)

UL 583, Standard for Electric Battery Powered Industrial Trucks (A-7-1.2)

#### Appendix C Schematics of Typical Pneumatic Conveying Installations

This Appendix is not a part of the requirements of this NFPA document, but is included for information purposes only.




Figure C-1 Multiple strand system, NEGATIVE PRESSURE-TYPE, typical for cereal mills.




Figure C-2 Typical car unloader system, NEGATIVE PRESSURE-TYPE, low capacity.




Figure C-3 Typical car unloader system, NEGATIVE PRESSURE-TYPE, high capacity.




Figure C-5 Typical transfer system, POSITIVE PRESSURE-TYPE, high capacity




Figure C-4 Portable car unloader and transfer system, combination NEGATIVE PRESSURE-TYPE, and POSITIVE PRESSURE-TYPE, high capacity.




Figure C-6 Typical transfer system, POSITIVE PRESSURE-TYPE, low capacity.





Figure C-7 Typical recirculating transfer system, POSITIVE PRESSURE-TYPE, high capacity.

Figure C-8 Typical recirculating transfer system, POSITIVE PRESSURE-TYPE, low capacity.



Fiugure C-9 Typical transfer system, combination POSITIVE PRESSURE-TYPE and NEGATIVE PRESSURE-TYPE, high capacity.

#### **Index**

©1990 National Fire Protection Association, All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document which it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of the National Fire Protection Association, Inc.

<b>-A-</b>	-Н-
Air-material separators	Headers       Chap. 2, A-2         Definition       1-4         Hoppers       5-1
Explosion prevention       4-4, A-4-4         Location       4-3         Primary       Definition       1-4	Hybrid mixtures 1-5.6, A-1-5.6.1 Definition 1-4
Protection	-I-
	Inspection, periodic8-2
-В-	
Blowers see Fans and blowers Bonding, portable conveying equipment	-М-
	Manifolds         Chap. 2, A-2           Definition         1-4
-C-	Motor driven equipment
Conveying units, portable see Dust, combustible Conveying units, portable	
	.р.
-D-	Pneumatic conveying system Definition
Design         1-5           Tubing, headers, manifolds, ducts         Chap. 2, A-2	Schematics of typical installations
Detachment         1-4           Drives         5-3	-R-
Ducts         Chap. 2, A-2           Definition         1-4           Return air         4-1.4	Retroactivity of standard1-3
Dust, combustible         1-4, A-1-4           Dust control, portable conveying equipment         7-3	-S-
Dust control, portable conveying equipment	Scope of standard
-E-	Sight glasses
Elbows         2-1.2           Engine and motor driven equipment         7-1, A-7-1	
inglife and motor direct equipment	-T-
-F-	Training, employee         8-1           Trucks, bulk         Chap. 7
Fans and blowersChap. 6Design and installation6-1Maintenance6-2Operation6-3	Tubing       Chap. 2, A-2         Definition       1-4
Feeding devices, mechanical       5-2, A-5-2         Feeding methods       Chap. 5	-V-
-G-	Valves         Chap. 3           Air flow control         3-3           Multiple direction         3-2
Grounding, portable conveying equipment	Pressure relief

### SUBMITTING PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

Contact NFPA Standards Administration for final date for receipt of proposals on a specific document.

#### **INSTRUCTIONS**

Please use the forms which follow for submitting proposed amendments.

Use a separate form for each proposal.

- 1. For each document on which you are proposing amendment indicate:
  - (a) The number and title of the document
  - (b) The specific section or paragraph.
- 2. Check the box indicating whether or not this proposal recommends new text, revised text, or to delete text.
- 3. In the space identified as "Proposal" include the wording you propose as new or revised text, or indicate if you wish to delete text.
- 4. In the space titled "Statement of Problem and Substantiation for Proposal" state the problem which will be resolved by your recommendation and give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If a statement is more than 200 words in length, the technical committee is authorized to abstract it for the Technical Committee Report.
- 5. Check the box indicating whether or not this proposal is original material, and if it is not, indicate source.
- 6. If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.
- 7. Type or print legibly in black ink.

NOTE: The NFPA Regulations Governing Committee Projects in Paragraph 10-10 state: Each proposal shall be submitted to the Council Secretary and shall include:

- (a) identification of the submitter and his affiliation (Committee, organization, company) where appropriate, and
- (b) identification of the document, paragraph of the document to which the proposal is directed, and
- (c) a statement of the problem and substantiation for the proposal, and
- (d) proposed text of proposal, including the wording to be added, revised (and how revised), or deleted.