



UL 428B

STANDARD FOR SAFETY

Electrically Operated Valves for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations Up To 20 Percent (B20), Kerosene, and Fuel Oil

ULNORM.COM : Click to view the full PDF of UL 428B 2022

UL Standard for Safety for Electrically Operated Valves for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations Up To 20 Percent (B20), Kerosene, and Fuel Oil, UL 428B

Second Edition, Dated August 22, 2022

Summary of Topics

This new edition of ANSI/UL 428B dated August 22, 2022 includes the deletion of redundant requirements and revisions to the Operations Test.

The new and revised requirements are substantially in accordance with Proposal(s) on this subject dated March 18, 2022 and July 8, 2022.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 428B 2022

AUGUST 22, 2022



ANSI/UL 428B-2022

1

UL 428B

**Standard for Electrically Operated Valves for Diesel Fuel, Biodiesel Fuel,
Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations Up To 20
Percent (B20), Kerosene, and Fuel Oil**

Prior to the first edition, the requirements for the products covered by this standard were included in the Outline of Investigation for Electrically Operated Valves for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations Up To 20 Percent (B20), Kerosene, and Fuel Oil, UL 428B.

First Edition – June, 2015

Second Edition

August 22, 2022

This ANSI/UL Standard for Safety consists of the Second Edition.

The most recent designation of ANSI/UL 428B as an American National Standard (ANSI) occurred on August 22, 2022. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2022 UNDERWRITERS LABORATORIES INC.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 428B 2022

CONTENTS

INTRODUCTION

1	Scope	5
2	Glossary	5

CONSTRUCTION

3	General	6
4	Materials	6
4.1	Metallic materials	6
4.2	Nonmetallic materials	6
4.3	Casting impregnation materials	8
4.4	Internal parts – fluid compatibility	8

PERFORMANCE

5	General	9
6	Long Term Exposure Test	10
6.1	General	10
6.2	Samples	10
6.3	Method	11
6.4	Results	11
7	Operation Test	12
8	External Leakage Test	12
9	Endurance Test	12
10	Hydrostatic Strength Test	13

MARKING

11	Details	13
----	---------------	----

SUPPLEMENT SA – MARINE USE ELECTRICALLY OPERATED SHUT-OFF VALVES FOR DIESEL FUEL, BIODIESEL FUEL, DIESEL/BIODIESEL BLENDS WITH NOMINAL BODIESEL CONCENTRATIONS UP TO 20 % (B20), KEROSENE, AND FUEL OIL

SA1	Scope	15
SA2	Installation and Operating Instructions	15
SA3	General	15
SA4	Materials	16
SA5	Electrical Connections	16
SA6	General	16
SA7	Vibration Test	16
SA8	Shock Test	16
SA9	Ignition Protection Test	17
SA10	Fire Test	17
SA11	Operation and Temperature Tests	19
SA11.1	Low temperature	19
SA11.2	Abnormal operation	19
SA11.3	Normal operation	19
SA12	Details	19

SUPPLEMENT SB – Test Fluids

UL COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER

SB.1	Representative Aggressive Combustible Test Fuel Mixtures	21
------	--	----

ULNORM.COM : Click to view the full PDF of UL 428B 2022

INTRODUCTION

1 Scope

1.1 These requirements cover electrically operated general purpose and safety valves rated 600 volts or less and intended for the control of the fluids specified in [1.2](#).

1.2 Electrically operated valves are intended for use with the following:

- a) Kerosene formulated in accordance with the Standard Specification for Kerosene, ANSI/ASTM D3699, and
- b) Fuel oil (heating oil) formulated in accordance with the Standard Specification for Fuel Oils, ANSI/ASTM D396, and
- c) Diesel fuel, which includes renewable diesel and diesel/biodiesel blends with nominal biodiesel concentrations up to 5 percent (B0 – B5) formulated in accordance with the Standard Specification for Diesel Fuel Oils, ANSI/ASTM D975, and
- d) Diesel/biodiesel, renewable diesel/biodiesel blends, blends with nominal biodiesel concentrations from 5 percent up to 20 percent (B6 – B20) formulated in accordance with the Standard Specification for Diesel Fuel Oil, Biodiesel Blends (B6 – B20), ANSI/ASTM D7467, and/or
- e) Biodiesel (B100) formulated in accordance with the Standard Specification for Biodiesel Fuel Blend Stock (B100) for Middle Distillate Fuels, ANSI/ASTM D6751.

1.3 These requirements do not cover valves for use with fluids other than as specified in [1.2](#).

1.4 These requirements do not cover valves employing electrical parts, including coils, switch contacts and resistance elements, located in the flammable gas containing compartment of a valve. Valves constructed as such shall comply with the requirements in the Standard for Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations, UL 913.

2 Glossary

2.1 For the purpose of this standard the following definitions apply.

2.2 DIESEL/BIODIESEL BLEND – Blended fuels composed of a diesel component and a biodiesel component. The numerical value corresponding to the biodiesel component determines the blend rating (such as B20 for 20 % biodiesel, 80 % diesel).

2.3 MAXIMUM RATED OPERATING PRESSURE DIFFERENTIAL – The maximum difference between the pressure at an inlet port and the pressure at an outlet port against which an electrically operated valve is intended to operate.

2.4 MAXIMUM RATED PRESSURE – The maximum pressure to which the valve assembly may be subjected as specified by the manufacturer.

2.5 MINIMUM RATED OPERATING PRESSURE DIFFERENTIAL – The minimum difference between the pressure at an inlet port and the pressure at an outlet port required for operation of the valve.

2.6 SEALS, DYNAMIC – A seal that is subject to mechanical movement or other applied forces that result in movement or flexing of the seal under normal use conditions.

2.7 SEALS, STATIC – A seal that is not subject to mechanical movement or other applied forces other than compression forces that are applied during installation and maintained during normal use conditions.

CONSTRUCTION

3 General

3.1 Electrically operated valves for diesel fuel, biodiesel fuel (B100), diesel/biodiesel blends with nominal biodiesel concentrations up to 20 % (B20), kerosene, and fuel oil service shall be constructed to comply with the following:

- a) The requirements defined in the Standard for Electrically Operated Valves, UL 429, and
- b) The requirements in this Standard.

3.2 Fluid confining parts, except gaskets and seals, shall be constructed of metallic materials.

4 Materials

4.1 Metallic materials

4.1.1 General

4.1.1.1 A metallic part, in contact with the fuels anticipated by these requirements, shall be resistant to the action of the fuel if degradation of the material will result in leakage of the fuel or if it will impair the function of the device. For all fuel ratings, see the Long Term Exposure Test, Section [6](#).

4.1.1.2 Metallic parts in contact with the fuels anticipated by these requirements shall not be constructed of lead, or materials that are substantially lead. In addition, no coatings or platings containing lead shall be used, such as terne-plated steel.

4.2 Nonmetallic materials

4.2.1 General

4.2.1.1 A nonmetallic part in contact with the fuels anticipated by these requirements, shall be resistant to the action of the fuel if degradation of the material will result in leakage of the fuel, or if it will impair the function of the device.

4.2.1.2 Gaskets or seals shall be designated as dynamic and/or static seals. See [2.6](#) and [2.7](#) respectively. If the type of seal cannot be determined, then the material shall be treated as both a static and a dynamic seal.

4.2.1.3 Gaskets and seals shall comply with the requirements as outlined in Nonmetallic materials – material level, [4.2.2](#) and Nonmetallic materials – system level, [4.2.3](#).

4.2.1.4 Nonmetallic materials in contact with the fuels anticipated by these requirements shall not be constructed of the following:

- a) Polysulfide rubber;
- b) Ethylene propylene diene monomer (EPDM) rubber;
- c) Methyl-Methacrylate;

- d) Polyvinyl Chloride (PVC); or
- e) Polyurethane as elastomer.

4.2.2 Nonmetallic materials – fluid compatibility – material level

4.2.2.1 Static seals

4.2.2.1.1 Static seals shall be evaluated in accordance with the Standard for Gaskets and Seals, UL 157, modified as indicated in [4.2.2.1.2](#) – [4.2.2.1.4](#). If a specific material complies with these requirements, the material can be considered to be qualified for system testing.

4.2.2.1.2 A static seal shall be constructed of a material that is acceptable in accordance with the scope of Standard for Gaskets and Seals, UL 157.

4.2.2.1.3 Static seals shall be subjected to the Volume Change and Extraction Test in accordance with the Standard for Gaskets and Seals, UL 157, except for the following modifications:

- a) The test duration shall be 1000 hours;
- b) The applicable test fluids shall be as described in Supplement [SB](#); and
- c) For all materials, the average volume change shall not exceed 40 % swell (increase in volume) or 1 % shrinkage (decrease in volume). In addition, the weight loss shall not exceed 10 %. For coated fabrics, alternate limits can be used with the average volume change not exceeding 60 % swell or 5 % shrinkage, and the weight loss shall not exceed 20 %. There shall be no visual evidence of cracking or other degradation as a result of the exposure for any material including coated fabrics.

4.2.2.1.4 Static seals shall be subjected to the Compression Set Test in accordance with the Standard for Gaskets and Seals, UL 157, except for the following modifications:

- a) The test duration shall be 1000 hours.
- b) The samples shall be immersed, at room temperature, in the test fluids [see (c)] while compressed for the entire test duration. No oven conditioning is required.
- c) The applicable test fluids shall be as described in Supplement [SB](#).
- d) The recovery period shall consist of removing the sample from the compression device and immersing it in the applicable test fluid for 30 minutes at room temperature. The sample shall not be allowed to dry out due to exposure to air. The 30-minute immersion should use the same fluid as the test fluid for each sample.
- e) For all materials, the average compressions set is calculated and shall not exceed 35 %. For coated fabrics, alternate limits can be used with the average compression set not exceeding 70 %.

Exception: This requirement does not apply to composite gasket materials as defined in accordance with the Standard for Gaskets and Seals, UL 157.

4.2.2.2 Dynamic seals

4.2.2.2.1 Dynamic seals shall be evaluated in accordance with the Standard for Gaskets and Seals, UL 157 modified as indicated in [4.2.2.2.2](#) – [4.2.2.2.4](#). If a specific material complies with these requirements, the material can be considered to be qualified for system testing.

4.2.2.2.2 A dynamic seal shall be constructed of a material that is acceptable in accordance with the scope of the Standard for Gaskets and Seals, UL 157.

4.2.2.2.3 Dynamic seals shall be subjected to the Volume Change and Extraction Test in accordance with the Standard for Gaskets and Seals, UL 157, except for the following modifications:

- a) The test duration shall be 1000 hours;
- b) The applicable test fluids shall be as described in Supplement [SB](#); and
- c) For all materials, the average volume change for a gasket or seal material shall not exceed 40 % swell (increase in volume) or 1 % shrinkage (decrease in volume). In addition, the weight loss shall not exceed 10 %. For coated fabrics, alternate limits can be used with the average volume change not exceeding 60 % swell or 5 % shrinkage, and the weight loss shall not exceed 20 %. There shall be no visual evidence of cracking or other degradation as a result of the exposure for any material including coated fabrics.

4.2.2.2.4 Dynamic seals shall be subjected to the Tensile Strength and Elongation Test in accordance with the Standard for Gaskets and Seals, UL 157, except for the following modifications:

- a) The test duration shall be 1000 hours;
- b) The applicable test fluids shall be as described in Supplement [SB](#); and
- c) For all materials, the average tensile strength and the average elongation of materials shall not be less than 60 % of the as-received values. For coated fabrics, alternate limits can be used with the average tensile strength and the average elongation not less than 30 % of the as-received values.

4.2.3 Nonmetallic materials – fluid compatibility – system level

4.2.3.1 For all materials, gaskets and seals that have been shown to comply with the applicable requirements for static seals in the Standard for Gaskets and Seals, UL 157, or with the requirements under material level tests shall be subjected to the system level tests for the applicable component after the Long Term Exposure Test, Section [6](#).

4.3 Casting impregnation materials

4.3.1 Material level fluid compatibility

4.3.1.1 The material shall be subjected to an infrared spectrum analysis in accordance with the Standard for Polymeric Materials – Short Term Property Evaluations, UL 746A.

4.3.2 System level fluid compatibility

4.3.2.1 The casting impregnation material, applied as intended to a casting, shall comply with the Long Term Exposure Test, Section [6](#). The casting shall not show indications of porosity leakage at any point during or after this test.

4.4 Internal parts – fluid compatibility

4.4.1 Nonmetallic parts located internally to a fluid confining part, degradation of which would not directly result in leakage, is not required to comply with Nonmetallic materials, [4.2](#). The part shall be tested in accordance with [4.4.2](#).

4.4.2 Internal nonmetallic parts shall be tested during the Long Term Exposure Test, Section 6. During this test, the part shall not degrade to the extent that visible particles can be observed in the fluid.

PERFORMANCE

5 General

5.1 Except as otherwise indicated, representative commercial sample(s) of a valve are to be subjected to the applicable tests described herein. The order of tests, as far as applicable, is to be as indicated in the specific test sequence shown in 5.6. In addition, except as noted in 5.3 or 5.4, the various tests are to be conducted at rated frequency and at the voltage indicated in Table 5.1. Additional samples of internal parts, such as diaphragms, seats, and the like, may be required for separate tests.

5.2 If a valve is rated at 50 hertz only, or 50/60 hertz, the input, temperature, overvoltage, undervoltage, and burnout tests may be conducted, with the concurrence of those concerned, at a frequency of 60 hertz and at a test voltage calculated as specified in 5.4.

Table 5.1
Test Voltages

Test	Voltage range ^{a,b,c}				
	110 – 120	220 – 240	257 – 277	440 – 480	550 – 600
All tests	120	240	277	480	600
^a If a 60-hertz rated coil has a voltage rating that does not fall within any of the indicated voltage ranges, it shall be tested at its rated voltage. ^b If coils rated for 60 hertz are supplied for various voltage ratings within a specified range (for example, 110, 115, or 117 volts), and if a coil is available for the maximum voltage rating of that range (120 volts), tests may be conducted on representative coils based on the marked voltage ratings of the coils selected for testing. If a coil is not available for the maximum voltage rating of that range, tests shall be conducted on all coils at the test potential indicated in this table. ^c If a coil is direct current (DC) or 50 hertz rated, the test voltage shall be based on the rated voltage. See 5.3 and 5.4.					

5.3 If a valve is rated at 50/60 hertz, and the test voltage calculated in accordance with 5.4 is less than or equal to the 60-hertz test voltage specified in Table 5.1, the input, temperature, overvoltage, undervoltage, and burnout tests are to be conducted at the higher voltage.

5.4 With reference to 5.2, the test voltage is to be based on increasing the current through the valve coil in accordance with the ratio of the impedance at the two frequencies for which the valve is rated. The test voltage is to be calculated from the following formula:

$$V_T = \frac{1.2 V_R V_M I_M}{\sqrt{(V_M I_M)^2 + 0.44 P_M^2}}$$

in which:

V_T is the test voltage;

V_R is the rated voltage at 50 hertz;

V_M is the rated voltage at 60 hertz, or $1.091 V_R$ if the valve has a frequency rating of 50 hertz only;

I_M is the input current measured at V_M at 60 hertz; and

P_M is the input power measured at V_M and 60 hertz.

5.5 All tests shall be performed using the test fluids specified for that test. No substitution of test fluids is allowed. When the test indicates that FB25a or B100a are to be used, the test fluid shall be prepared as described in Supplement [SB](#).

5.6 The following test sequence outlines the order in which tests shall be performed. Tests included in this standard, but not included in the test sequence, can be performed in any order in accordance with [5.1](#). The tests in the given sequence are to be performed on samples that were subjected to the Long Term Exposure Test, Section [6](#). One sample of the valve is required for each applicable test fluid, and that sample shall then be subjected to the sequence.

- a) Long Term Exposure Test, Section [6](#);
- b) External Leakage Test, Section [8](#);
- c) Operation Test, Section [7](#);
- d) Endurance Test, Section [9](#);
- e) Operation Test, Section [7](#);
- f) External Leakage Test, Section [8](#); and
- g) Hydrostatic Strength Test, Section [10](#).

5.7 To reduce the effects of seal dry out due to removal of the test fluid after specific tests, the tests in the given sequence in [5.6](#), shall be started within 4 hours of removal of the previous test fluid. If necessary to coordinate testing, the sample may be left filled with the most recent test fluid at room temperature until the next test is initiated. If the previous test used an aerostatic or hydrostatic source, the sample shall be filled with kerosene.

5.8 A valve that must be mounted in a definite position in order to function as intended is to be tested in that position if directions for mounting in the correct position are given on the valve or in an instruction sheet supplied with the valve.

6 Long Term Exposure Test

6.1 General

6.1.1 The test outlined in [6.2](#) – [6.4](#) is to be performed on one or two samples of the valve, with one sample for each rating. If the product is rated for use with diesel fuel, diesel/biodiesel blends with biodiesel concentrations up to 20 % (B20), kerosene, or fuel oil, then the test shall be performed using the FB25a test fluid. If the product is rated for use with a biodiesel fluid (B100), then the test shall be performed using the B100a test fluid. See Supplement [SB](#).

6.2 Samples

6.2.1 A sample of a complete valve is to be tested. All inlet and outlet openings of the samples shall be sealed in accordance with [6.2.3](#).

6.2.2 If platings or coatings are used internal to the device, additional samples may be used. See [6.4.2](#).

6.2.3 Closures shall be provided to seal off inlet and outlet openings of all samples in accordance with [6.2.1](#). These closures shall be fabricated of suitable materials. The closures shall be provided with a 1/4 inch NPT opening for connection to the test apparatus. All closures shall be installed by the manufacturer

and provided with a torque rating. There will be no other adjustment to connections for the duration of the test.

6.2.4 Any o-rings, gaskets, or other sealing materials, shall be provided and installed by the manufacturer. These dynamic sealing devices shall be the same as those that will be used in the final product installation. Static seals shall be representative of the seals being used in the final product installation. If the sealing device or material is not considered part of the component under test, but will be provided in an end product at the time of installation, a representative seal shall be provided for the test.

6.3 Method

6.3.1 The sample is to be exposed to the applicable test fluid in accordance with [6.1.1](#). The test fluids shall be prepared using the instructions in Supplement [SB](#).

6.3.2 A quick connect device is connected to the 1/4 inch NPT connection at the inlet, and is used to fill the samples with the applicable test fluids. A source of pressure may be used to assist in filling or draining the samples, however, the pressure shall not exceed the rated pressure of the valve under test. Once the samples are filled to exclude all air, they are closed off and sealed. The samples are then placed in the test chamber.

6.3.3 The chamber temperature is increased to 60 ± 2 °C (140 ± 4 °F). When the chamber reaches this temperature, the exposure period begins. The samples are exposed to the applicable test fluid at 60 ± 2 °C for approximately 168 hours. At the end of this duration, the exposure period is halted and the chamber is allowed to cool. The samples are subjected to a 50 psi (347 kPa) pressure for one minute. The fluid is then drained from the samples and observed in accordance with [6.4.2](#). After this observation, the fluid is discarded. The samples are then immediately refilled with new test fluid and the chamber temperature is allowed to increase to 60 ± 2 °C again. The total duration of the test shall equal 1008 hours of exposure at 60 ± 2 °C.

6.3.4 At the end of the total exposure duration, the test fluid is left in the samples and the samples are removed from the chamber. The samples are then subjected to the test sequence as outlined in [5.6](#) and in accordance with [5.7](#). Prior to the initiation of the test sequence, the Long Term Exposure test fluid is to be drained and discarded.

6.3.5 If the device contains any parts or surfaces that are plated or coated, if the device uses casting impregnation materials to eliminate porosity leakage, or if the device contains internal nonmetallic parts, the plating, coating, impregnation, or internal parts are tested both during and after this exposure. See [6.4.2](#) and [6.4.4](#).

6.4 Results

6.4.1 There shall be no leakage during this test. If leakage is observed at any point during the test, the test is to be stopped.

6.4.2 For platings or coatings, there shall be no softening of the plating or coating material. Compliance is checked by observance of the drained test fluid. There shall be no evidence of visible flaking or material. In addition, there shall be no substantial discoloration of the test fluid when observing the drained fluid. Discoloration is an indication of chemical attack on the plating or coating internal to the device. In order to determine that the base metal is not exposed, visual inspections shall be made. If the visual inspection requires examination of internal surfaces, the samples shall be cut open to determine compliance. If this is necessary, additional samples can be used to determine compliance with this requirement, such that the remaining test sequence will not be disturbed by cutting open samples. However, both the samples to be cut open and the samples to be used for the test sequence are required to complete the Long Term Exposure Test.

6.4.3 For casting impregnation materials, the sample shall not show evidence of porosity leakage during or after the fluid exposure duration.

6.4.4 For internal nonmetallic parts, there shall be no visible evidence of this material in the drained test fluid.

7 Operation Test

7.1 A valve shall handle kerosene or Soltrol 170 at the maximum rated operating pressure differential. The test is to be repeated at the minimum rated operating pressure differential if the valve is so rated.

7.2 A valve rated for use in ambient temperatures greater than 25 °C (77 °F) or for handling a fluid at temperatures greater than 25 °C, or both, is to be tested in accordance with [7.3](#) at the maximum rated temperatures.

7.3 The inlet of the valve is to be connected to a suitable system that can deliver the test fluid under pressure. The valve shall be in an open position with the fluid flowing. The valve shall then be closed and the outlet shall be observed for signs of fluid flow. There shall be no continued flow of fluid from the valve outlet.

8 External Leakage Test

8.1 A valve shall not leak externally when tested with hydrostatically at a pressure of one and one-half times the maximum rated pressure but not less than 1/2 psig (3.5 kPa) with the valve in the open position and the outlet closed for a period of 1 hr.

8.2 The inlet of the valve is to be connected to a hydrostatic source capable of supplying the specified test pressure. The outlet of the valve is to be sealed. Any bypass or other openings not essential to the operation of the valve during this test are to be sealed unless this discharge in the main fluid stream before the outlet of the valve. The test fluid is to be admitted and maintained at the specified test pressure. In the case of diaphragm elements which, in intended usage, are subjected to pressure on both sides of the diaphragm, the test pressure is to be applied to both sides of the diaphragm slowly and without shock.

9 Endurance Test

9.1 A valve intended for use with the fuels anticipated by these requirements, shall be subjected to 100,000 cycles of open and close action at the maximum rated operating pressure differential. At the end of the 100,000 cycles, the valve shall operate as intended and shall not leak externally.

9.2 The endurance test is to be conducted at a rate not faster than six operations per minute. However, a rate greater than six operations per minute may be used if requested by the manufacturer.

9.3 For valves intended to handle the fuels anticipated by these requirements at ambient or fluid temperatures above room temperature, the fluid is to be the higher of the rated fluid and ambient temperature.

9.4 A valve is to be tested with kerosene or Soltrol 170 as the test fluid.

9.5 This test is to be performed after the Long Term Exposure Test, Section [6](#), in accordance with [5.6](#).

9.6 The appropriate tests for operation and external leakage are to be conducted before and after the endurance test in accordance with the test sequence shown in [5.6](#).

10 Hydrostatic Strength Test

10.1 All parts of a valve, except a diaphragm, that are subjected to pressure during intended operation shall be tested hydrostatically to determine that the strength of the parts is sufficient to withstand, without rupture, a pressure equivalent to five times the maximum rated pressure of the valve.

10.2 The valve is to be tested by connecting the inlet to a hydraulic system. With the outlet of the valve sealed and the valve in the open position, the pressure is to be raised slowly to the required test pressure and held for a period of 1 minute. In the case of a diaphragm valve, the test pressure is to be applied on both sides of the diaphragm slowly and without shock to avoid excessively stressing the diaphragm.

10.3 External leakage observed during this test is acceptable provided the test pressure can be maintained for the entire test duration, and if, following the hydrostatic test, the valve complies with the requirements for external leakage specified in Section [8](#).

MARKING

11 Details

11.1 The following information shall be permanently marked on each valve.

a) Valves shall be marked to indicate the fuel rating for which they are intended. The marking shall be "Diesel Fuel" or "B5" for valves rated for diesel fuel only, shall be "B20" for valves rated for diesel fuel and diesel fuel/biodiesel blends with nominal biodiesel concentrations up to 20 % biodiesel (B0 – B20), shall be "B100" for valves rated for biodiesel fuel, "Kerosene" for valves rated for kerosene, or "Fuel Oil" for valves rated for use with fuel oil. This marking shall be prominently displayed to identify the valve.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 428B 2022

SUPPLEMENT SA – MARINE USE ELECTRICALLY OPERATED SHUT-OFF VALVES FOR DIESEL FUEL, BIODIESEL FUEL, DIESEL/BIODIESEL BLENDS WITH NOMINAL BIODIESEL CONCENTRATIONS UP TO 20 % (B20), KEROSENE, AND FUEL OIL

SA1 Scope

SA1.1 The requirements in this supplement cover electrically operated shut-off valves rated 50 volts or less intended to be used on boats with the fuels anticipated by these requirements.

SA1.2 The products covered by the requirements in this supplement are intended for installation in accordance with the manufacturer's instructions and the applicable requirements of the Fire Protection Standard for Pleasure and Commercial Motor Craft, NFPA 302; the applicable requirements of the American Boat and Yacht Council (ABYC); and the applicable requirements of the United States Coast Guard (USCG).

SA1.3 A product intended for marine use shall comply with the requirements in Sections [3](#) – [10](#), as applicable, except as modified or superseded by the requirements in this supplement.

SA2 Installation and Operating Instructions

SA2.1 The manufacturer shall provide complete installation and operating instructions with each valve. The instructions shall include recommendations relative to the use of thread compound, recommendations on proper wire size and fusing, mounting instructions and any other data necessary for the proper installation and operation of the valve.

SA2.2 The operating instruction shall specifically cover the operation of any manual by-pass valve and shall include the statement "Caution – Risk of Fire," and the following or equivalent statement, "The electric valve will not function as a shut-off valve with the by-pass open." In addition, the manufacturer shall provide the following operating data for gasoline, diesel oil, or other liquids for which the valve is intended to be used:

- a) The maximum operating pressure.
- b) The flow capacity in gallons per minute or hour, as related to the pressure differential or pressure differential or pressure drop between the inlet and outlet, for specific liquids.

SA3 General

SA3.1 A valve intended to be used in the fuel feed system to propulsion engines shall be equipped with a manual emergency by-pass.

SA3.2 A valve used in the fuel feed lines to non-vital equipment, such as heater, auxiliary generator, and the like, shall not incorporate a manual by-pass.

SA3.3 A diaphragm type valve shall be constructed so that a damaged diaphragm will not cause external leakage.

SA3.4 A valve shall be provided with means for mounting independent of the fuel line.

SA3.5 A valve shall be constructed so that it will unseat before the pressure on the valve outlet exceeds 1000 psi (6895 kPa) in order to prevent pressure from building up in trapped sections of the fuel line due to heat. See the Fire Test, Section [SA11](#).

SA3.6 A valve shall be capable of operating in any orientation without leakage or malfunction.

SA4 Materials

SA4.1 All materials shall comply with the requirements in Materials, Section [4](#).

SA4.2 A metallic part shall be formed from AISI 300 or 400 Series stainless steel or other material having at least equivalent resistance to the corrosive effects of salt spray as determined by the Standard Practice for Operating Salt Spray (Fog) Apparatus, ASTM B117.

SA5 Electrical Connections

SA5.1 An electrical connection for low-voltage DC circuits operating at less than 32 volts shall be made by means of a two prong plug, two insulated terminals, or by means of a pigtail for use with an external junction box or block.

SA5.2 Exposed uninsulated terminals shall not be used.

SA5.3 A pigtail lead, if used for field wiring, shall be at least 16 AWG (1.3 mm²) stranded copper wire and no less than 8 inches (203 mm) in length.

SA5.4 An actuating coil shall be constructed for a two wire system without an electrical ground.

SA6 General

SA6.1 The same sample is to be used for the Vibration Test, the Shock Test, and the Ignition Protection Test, Sections [SA7](#) – [SA9](#), respectively.

SA6.2 The same sample used for the Long Term Exposure Test, Section [6](#), is to be used for the Fire Test, Section [SA10](#).

SA7 Vibration Test

SA7.1 A valve shall function as intended without increasing the risk of fire or explosion following the vibration conditioning specified in [SA7.2](#) – [SA7.4](#). There shall not be evidence of leakage, and there shall not be fluid flow due to vibration.

SA7.2 The valve specified in [SA6.1](#), with tubing sections connected in accordance with the manufacturer's instructions, is to be rigidly mounted directly to the surface of a vibration table in its normal operating position. The valve is to be subjected to a pressure of 10 psi (69 kPa) on the valve inlet when the valve is closed during the conditioning.

SA7.3 The assembly specified in [SA7.2](#) is to be subjected to variable frequency vibration along each of three rectilinear orientation axes (horizontal, lateral, and vertical) for 4 hours in each plane (12 hours total) at a peak-to-peak amplitude of 0.060 ±0.001 inches (1.5 ±0.025 mm). The frequency of vibration is to continuously varied, at a uniform rate, from 10 to 60 to 10 Hz every 4 minutes.

SA7.4 During the first hour of conditioning in each separate plane, the valve is to be energized. The valve is to be unenergized during the last three hours of conditioning; except for the last ten minutes in which the valve is to be randomly cycled on and off to check for leakage.

SA8 Shock Test

SA8.1 The same valve used for the Vibration Test, Section [SA7](#), shall function as intended without increasing the risk of fire or explosion following the conditioning specified in [SA8.2](#) – [SA8.4](#). There shall not be evidence of leakage and no fluid flow due to shock.